

Randolph Hall

Southwest Oregon CC

Coos_coc04A

Building Type Community_College	County Coos	
Street 1988 Newmark Ave		
City Coos Bay	State OR	Zip 97420
Latitude 43.39513	Longitude 124.25284	
Tracking Code Miller 2004-05	Inspection Date 7/14/2005	

Seismicity Zone: Very High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	C2	2.8	-1	-0.5	0	0	0	-0.6	0	0.7
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Randolph Hall


Final RVS Score

Final Type
C2

Final Score
0.7

FEMA-154 Collapse Potential

High (>10%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Randolph Hall

Coos_coc04A

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
	1964	1964	1960
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
12836	1	No	No
Plan Irregularities		Vertical Irregularities	
None		None	
Falling Hazards		Poor Conditions	
None			
None			
None			



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries