

Coos Bay Fire Station - Empire

City of Coos Bay

Coos_fir02A

Building Type Fire - City	County Coos	
Street 189 S Wall St		
City Coos Bay	State OR	Zip 97420
Latitude 43.39113	Longitude 124.27535	
Tracking Code RVS in 2006	Inspection Date 8/18/2006	



Seismicity Zone: Very High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	C2	2.8	0	-0.5	-1	0	-0.4	0	0	0.9
Secondary	W1	4.4	0	-0.5	0	0	0	0	0	3.9
Tertiary		0	0	0	0	0	0	0	0	0

Coos Bay Fire Station - Empire

Final RVS Score

Final Type	Final Score
C2	0.9

FEMA-154 Collapse Potential

High (>10%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Coos Bay Fire Station - Empire

Coos_fir02A

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
			1940
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
	2	Yes	No
Plan Irregularities		Vertical Irregularities	
Torsion: Eccentric Stiffness		None	
Out of Plane Lateral-Force-Resistance Elements		None	
None		None	
Falling Hazards		Poor Conditions	
None		Poor Concrete	
None		None	
None		None	
			
SW Secondary Structural Type		SW Plan Irregularity Secondary	
		SW Basement	
		E Poor Condition	



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries