

# Coos Bay Fire Station - Central

City of Coos Bay

Coos\_fir03A

Building Type Fire - City	County Coos	
Street 150 S 4th St.		
City Coos Bay	State OR	Zip 97420
Latitude 43.36747	Longitude 124.21571	
Tracking Code RVS in 2006	Inspection Date 8/14/2006	



Seismicity Zone: Very High

## FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	C2	2.8	-1	-0.5	0	0	-0.4	0	0	0.9
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Coos Bay Fire Station - Central

## Final RVS Score

Final Type	Final Score
C2	0.9

## FEMA-154 Collapse Potential

High (>10%)



OregonGeology

# Coos Bay Fire Station - Central

Coos\_fir03A

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
	1955	1955	1950
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
	2	No	No
Plan Irregularities		Vertical Irregularities	
Reentrant Corners:Other (Adjacent Build/Entity)		Soft Story	
Torsion: Eccentric Stiffness		None	
None		None	
Falling Hazards		Poor Conditions	
None		None	
None		None	
None		None	
			
SE General Site Back wall is solid and front wall is open indicating a possible torsion problem.			



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment  
Oregon Department of Geology and Mineral Industries