

Coos Bay Fire Station - Eastside

City of Coos Bay

Coos_fir04A

Building Type Fire - City	County Coos	
Street 365 D St		
City Coos Bay	State OR	Zip 97420
Latitude 43.36484	Longitude 124.196	
Tracking Code RVS in 2006	Inspection Date 8/14/2006	



Seismicity Zone: Very High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	C2	2.8	-1	-0.5	-1	0	0	-0.6	0	-0.3
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Coos Bay Fire Station - Eastside

Final RVS Score

Final Type	Final Score
C2	-0.3

FEMA-154 Collapse Potential

Very High (100%)



OregonGeology

Coos Bay Fire Station - Eastside

Coos_fir04A

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
			1940
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
	2	No	No
Plan Irregularities		Vertical Irregularities	
Torsion: Eccentric Stiffness		Steps in Elevation View: Single Change	
None		None	
None		None	
Falling Hazards		Poor Conditions	
Unreinforced Chimneys		None	
Other: General		None	
None		None	
			
S	Vertical Irregularity Primary	NE	Primary Structural Type
			
		N Falling Hazard Unreinforced chimney and tall concrete wall (> 6 ft)	



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries