

North Bend Fire

Coos_fir08A

City of North Bend

Building Type	County
Fire - City	Coos
Street	
1880 McPherson St	
City	State Zip
North Bend	OR 97459
Latitude	Longitude
43.40822	124.22655
Tracking Code	Inspection Date
RVS in 2006	8/10/2006



Seismicity Zone: Very High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	3.8	-2	-0.5	0	0	0	-0.8	0	0.5
Secondary	C2	2.8	-1	-0.5	0	0	0	-0.6	0	0.7
Tertiary		0	0	0	0	0	0	0	0	0

North Bend Fire

Final RVS Score

Final Type	Final Score
W2	0.5

FEMA-154 Collapse Potential

High (>10%)



OregonGeology

North Bend Fire

Coos_fir08A

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
			1960
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
	2	No	No
Plan Irregularities		Vertical Irregularities	
Reentrant Corners: Other		Steps in Elevation View: 2 to 3 Changes	
None		Building On Hill or Sloped Site	
None		None	
Falling Hazards		Poor Conditions	
None		None	
None		None	
None		None	
			
SE Plan Irregularity Primary		SW General Site sloped site due to grading plan.	
		W Vertical Irregularity Primary	
		W Secondary Structural Type	



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries