

# Greenacres RFPD

Greenacres RFPD

Coos\_fir11A

|                                |                              |              |
|--------------------------------|------------------------------|--------------|
| Building Type<br>Fire - RFPD   | County<br>Coos               |              |
| Street<br>93449 Greenacres Ln. |                              |              |
| City<br>Coos Bay               | State<br>OR                  | Zip<br>97420 |
| Latitude<br>43.26484           | Longitude<br>124.19225       |              |
| Tracking Code<br>RVS in 2006   | Inspection Date<br>8/18/2006 |              |



Seismicity Zone: Very High

## FEMA 154 Rapid Visual Screening Score Card

|           | Type | Basic Score | Vert Irreg | Plan Irreg | Pre-Code | Post-Bench | Soil C | Soil D | Soil E | RVS Score |
|-----------|------|-------------|------------|------------|----------|------------|--------|--------|--------|-----------|
| Primary   | W1   | 4.4         | -2.5       | -0.5       | 0        | 0          | 0      | 0      | 0      | 1.4       |
| Secondary |      | 0           | 0          | 0          | 0        | 0          | 0      | 0      | 0      | 0         |
| Tertiary  |      | 0           | 0          | 0          | 0        | 0          | 0      | 0      | 0      | 0         |

Greenacres RFPD

## Final RVS Score

| Final Type | Final Score |
|------------|-------------|
| W1         | 1.4         |

## FEMA-154 Collapse Potential

Moderate (>1%)



OregonGeology

# Greenacres RFPD

Coos\_fir11A

|  |                             |   |                    |
|--|-----------------------------|---|--------------------|
| Enrollment   | Year Built (Field Verified) | Year Built (Alt. Source)                | Est. Decade Built  |
|  |                             |   | 1970               |
| Total Area (square ft)   | Number of Stories           | Basement                                | Pounding Potential |
|  | 2                           | No                                      | No                 |
| Plan Irregularities  |                             | Vertical Irregularities                 |                    |
| Torsion: Eccentric Stiffness   |                             | Steps in Elevation View: 2 to 3 Changes |                    |
| None   |                             | None                                    |                    |
| None   |                             | None                                    |                    |
| Falling Hazards  |                             | Poor Conditions                         |                    |
| None   |                             | None                                    |                    |
| None   |                             | None                                    |                    |
| None   |                             | None                                    |                    |
|  |                             |   |                    |
| S Vertical Irregularity Primary  |                             |   |                    |



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment  
Oregon Department of Geology and Mineral Industries