

Building Type		County	
Fire - RFPD		Coos	
Street			
93622 Viking Ln			
City	State	Zip	
North Bend	OR	97459	
Latitude	Longitude		
43.5018	124.21316		
Tracking Code	Inspection Date		
RVS in 2006	8/18/2006		



Seismicity Zone: Very High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	S3	3.2	0	-0.5	0	0	0	-0.6	0	2.1
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Hauser RFPD

Final RVS Score

Final Type

Final Score

S3

2.1

FEMA-154 Collapse Potential

Low (<1%)



Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
			1970
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
	1	No	No

Plan Irregularities	Vertical Irregularities
Torsion: Eccentric Stiffness	None
None	None
None	None

Falling Hazards	Poor Conditions
None	None
None	None
None	None



SW General Site