

Lakeside RFPD

Lakeside RFPD

Coos_fir15A

Building Type Fire - RFPD	County Coos									
Street 115 North 9th St										
City Lakeside	State OR	Zip 97449								
Latitude 43.57621	Longitude 124.1745									
Tracking Code RVS in 2006	Inspection Date 8/18/2006									
Seismicity Zone: Very High										
FEMA 154 Rapid Visual Screening Score Card										
	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	RM1	2.8	0	-0.5	0	0	0	-0.6	0	1.7
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Lakeside RFPD

Final RVS Score

Final Type RM1	Final Score 1.7
-------------------	--------------------

FEMA-154 Collapse Potential

Moderate (>1%)







OregonGeology

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
	1963	1963	1960
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
	2	No	No
Plan Irregularities		Vertical Irregularities	
Torsion: Eccentric Stiffness		Steps in Elevation View: Single Change	
Reentrant Corners: Other		Steps in Elevation View: Single Change (Adjacent Building/Entity)	
None		None	
Falling Hazards		Poor Conditions	
None		None	
None		None	
None		None	
 <p>OF 10 YEARS OF SERVICE 1956-1972</p> <p>LAKESIDE R.F.P.D. BUILDING ERECTED 1963</p> <p>M. R. MOFFITT - PRESIDENT M. L. FORSELL - VICE PRES.</p> <p>DIRECTORS ALVIN JOHNSTON</p>		 <p>SW Vertical Irregularity Secondary</p>	
E	Field Verified Year Built	SW	Plan Irregularity Secondary
 <p>NW Vertical Irregularity Primary</p>			



Lakeside RFPD

Lakeside RFPD

Coos_fir15B

Building Type Fire - RFPD	County Coos	
Street 115 North 9th St		
City Lakeside	State OR	Zip 97449
Latitude 43.57621	Longitude 124.17466	
Tracking Code RVS in 2006	Inspection Date 8/18/2006	

Seismicity Zone: Very High

FEMA 154 Rapid Visual Screening Score Card										
	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	RM1	2.8	-1	-0.5	0	0	0	-0.6	0	0.7
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Lakeside RFPD

Final RVS Score

Final Type RM1	Final Score 0.7
-------------------	--------------------

FEMA-154 Collapse Potential

High (>10%)



OregonGeology

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
	1972	1963	1970
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
	1	No	No
Plan Irregularities		Vertical Irregularities	
Reentrant Corners:Other (Adjacent Build/Entity)		Steps in Elevation View: Single Change (Adjacent Building/Entity)	
None		None	
None		None	
Falling Hazards		Poor Conditions	
None		None	
None		None	
None		None	
			
SW Vertical Irregularity Primary		SW Plan Irregularity Primary	



Lakeside RFPD

Lakeside RFPD

Coos_fir15C

Building Type Fire - RFPD	County Coos									
Street 115 North 9th St										
City Lakeside	State OR	Zip 97449								
Latitude 43.57635	Longitude 124.17455									
Tracking Code RVS in 2006	Inspection Date 8/18/2006									
Seismicity Zone: Very High										
FEMA 154 Rapid Visual Screening Score Card										
	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W1	4.4	0	-0.5	0	2.4	0	0	0	6.3
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Lakeside RFPD

Final RVS Score

Final Type W1	Final Score 6.3
------------------	--------------------

FEMA-154 Collapse Potential

Low (<1%)







Oregon Geology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
		1963	1990
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
	1	No	No
Plan Irregularities		Vertical Irregularities	
Torsion: Eccentric Stiffness		None	
Reentrant Corners: Other		None	
None		None	
Falling Hazards		Poor Conditions	
None		None	
None		None	
None		None	
			
NW Plan Irregularity Secondary			

