

# Bridge Rural Fire

Coos\_fir26A

Bridge RFPD

Building Type Fire - RFPD	County Coos	
Street 98183 Bridge Ln		
City Myrtle Point	State OR	Zip 97458
Latitude 43.0258	Longitude 124.00991	
Tracking Code RVS in 2006	Inspection Date 8/10/2006	



Seismicity Zone: Very High

## FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	S3	3.2	0	-0.5	0	0	-0.4	0	0	2.3
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Bridge Rural Fire

## Final RVS Score

Final Type	Final Score
S3	2.3

## FEMA-154 Collapse Potential

Low (<1%)



OregonGeology

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
			1970
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
	1	No	No
Plan Irregularities		Vertical Irregularities	
Torsion: Eccentric Stiffness		Steps in Elevation View: Single Change	
None		None	
None		None	
Falling Hazards		Poor Conditions	
None		None	
None		None	
None		None	
			
E Vertical Irregularity Primary			

