

# North Bay RFPD

North Bay RFPD

Coos\_fir29A

Building Type Fire - RFPD	County Coos	
Street 67577 East Bay Rd		
City North Bend	State OR	Zip 97459
Latitude 43.43454	Longitude 124.21237	
Tracking Code RVS in 2006	Inspection Date 8/18/2006	



Seismicity Zone: Very High

## FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	RM1	2.8	-1	-0.5	0	0	-0.4	0	0	0.9
Secondary	W1	4.4	-2.5	-0.5	0	2.4	0	0	0	3.8
Tertiary		0	0	0	0	0	0	0	0	0

North Bay RFPD

## Final RVS Score

Final Type	Final Score
RM1	0.9

## FEMA-154 Collapse Potential

High (>10%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment  
Oregon Department of Geology and Mineral Industries

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
			1980
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
	1	No	No
Plan Irregularities		Vertical Irregularities	
Torsion: Eccentric Stiffness		Steps in Elevation View: 2 to 3 Changes	
Reentrant Corners: Other		None	
None		None	
Falling Hazards		Poor Conditions	
None		None	
None		None	
None		None	
			
NW Plan Irregularity Primary		SE Vertical Irregularity Primary	

