

Dora-Sitkum RFPD

Dora-Sitkum RFPD

Coos_fir30A

Building Type Fire - RFPD	County Coos	
Street 56127 Gold Brick Rd.		
City Myrtle Point	State OR	Zip 97458
Latitude 43.15427	Longitude 123.95512	
Tracking Code RVS in 2006	Inspection Date 8/10/2006	



Seismicity Zone: Very High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W1	4.4	-2.5	-0.5	0	0	0	0	0	1.4
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Dora-Sitkum RFPD

Final RVS Score

Final Type	Final Score
W1	1.4

FEMA-154 Collapse Potential

Moderate (>1%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
			1930
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
	1	No	No
Plan Irregularities		Vertical Irregularities	
Reentrant Corners: Other		Steps in Elevation View: Very Irregular Changes	
None		None	
None		None	
Falling Hazards		Poor Conditions	
Unreinforced Chimneys		None	
None		None	
None		None	
			
SW	Plan Irregularity Primary	W	Falling Hazard
		<p>E Other The building has some patches on the back.</p>	

