

North Bend Fire

City of North Bend

Coos_fir31A

Building Type		County	
Fire - City		Coos	
Street			
1837 E Airport Way			
City	State	Zip	
North Bend	OR	97459	
Latitude		Longitude	
43.41499		124.24562	
Tracking Code		Inspection Date	
RVS in 2006		8/18/2006	



Seismicity Zone: Very High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	RM1	2.8	-1	-0.5	0	0	0	-0.6	0	0.7
Secondary	C2	2.8	-1	-0.5	0	0	0	-0.6	0	0.7
Tertiary	W1	4.4	-2.5	-0.5	0	0	0	0	0	1.4

North Bend Fire

Final RVS Score

Final Type

Final Score

RM1

0.7

FEMA-154 Collapse Potential

High (>10%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
			1950
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
	2	No	No

Plan Irregularities	Vertical Irregularities
Reentrant Corners: L Shaped	Steps in Elevation View: Single Change
Torsion: Eccentric Stiffness	None
None	None

Falling Hazards	Poor Conditions
None	None
None	None
None	None



SW Plan Irregularity Primary



SE Plan Irregularity Secondary