

# North Bend Fire

Coos\_fir32A

City of North Bend

Building Type Fire - City	County Coos	
Street 2222 Newmark St		
City North Bend	State OR	Zip 97459
Latitude 43.39177	Longitude 124.24295	
Tracking Code RVS in 2006	Inspection Date 8/18/2006	



Seismicity Zone: Very High

## FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W1	4.4	-2.5	-0.5	0	2.4	0	0	0	3.8
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

North Bend Fire

## Final RVS Score

Final Type	Final Score
W1	3.8

## FEMA-154 Collapse Potential

Low (<1%)



OregonGeology

# North Bend Fire

Coos\_fir32A

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
			1990
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
	2	No	No
Plan Irregularities		Vertical Irregularities	
Torsion: Eccentric Stiffness		Steps in Elevation View: Single Change	
None		None	
None		None	
Falling Hazards		Poor Conditions	
None		None	
None		None	
None		None	
			
NW Vertical Irregularity Primary			



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment  
Oregon Department of Geology and Mineral Industries