

North Bend Police Dept

City of North Bend

Coos_pol01A

Building Type Police - City	County Coos	
Street 835 California St		
City North Bend	State OR	Zip 97459
Latitude 43.40753	Longitude 124.22575	
Tracking Code RVS in 2006	Inspection Date 8/18/2006	



Seismicity Zone: Very High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	3.8	-2	-0.5	-1	0	0	-0.8	0	-0.5
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

North Bend Police Dept

Final RVS Score

Final Type	Final Score
W2	-0.5

FEMA-154 Collapse Potential

Very High (100%)



OregonGeology

North Bend Police Dept

Coos_pol01A

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
	1939	1939	1930
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
	2	Yes	No
Plan Irregularities		Vertical Irregularities	
Reentrant Corners: Other		Steps in Elevation View: Single Change	
None		None	
None		None	
Falling Hazards		Poor Conditions	
Other: Brick Veneer		None	
None		None	
None		None	



E Vertical Irregularity Primary



E Field Verified Year Built



E Falling Hazard



NW General Site



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries