

Coos Bay Police Dept

City of Coos Bay

Coos_pol02A

Building Type	County
EOC-Public Safety Answering P	Coos
Street	
500 W Central Ave	
City	State Zip
Coos Bay	OR 97420
Latitude	Longitude
43.36794	124.21743
Tracking Code	Inspection Date
RVS in 2006	8/14/2006



Seismicity Zone: Very High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	C1	2.5	-1.5	0	0	0	-0.4	0	0	0.6
Secondary	C2	2.8	-1	0	0	0	-0.4	0	0	1.4
Tertiary	W2	3.8	-2	0	0	0	-0.4	0	0	1.4

Coos Bay Police Dept

Final RVS Score

Final Type	Final Score
C1	0.6

FEMA-154 Collapse Potential

High (>10%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Coos Bay Police Dept

Coos_pol02A

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
			1970
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
	2	No	No
Plan Irregularities		Vertical Irregularities	
None		Soft Story	
None		Vertical Change in Structural Type (Soft over Stiff)	
None		None	
Falling Hazards		Poor Conditions	
None		None	
None		None	
None			
			
E	Primary Structural Type	W	Secondary Structural Type
			
NW	Tertiary Structural Type		
			
NE	Other		
Two masonry rooms on the first floor (NE ,SE). Can not tell what they are for.			



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries