

OSP

Oregon State Police

Coos\_pol04A

Building Type Police - State	County Coos	
Street 155 N Schoneman Ave		
City Coos Bay	State OR	Zip 97420
Latitude 43.39271	Longitude 124.26782	
Tracking Code RVS in 2006	Inspection Date 8/18/2006	



Seismicity Zone: Very High

#### FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	S3	3.2	0	-0.5	0	0	-0.4	0	0	2.3
Secondary	W1	4.4	-2.5	-0.5	0	0	0	0	0	1.4
Tertiary		0	0	0	0	0	0	0	0	0

OSP

#### Final RVS Score

Final Type	Final Score
W1	1.4

#### FEMA-154 Collapse Potential

Moderate (>1%)



Oregon Geology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment  
Oregon Department of Geology and Mineral Industries

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
			1970
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
	1	No	No
Plan Irregularities		Vertical Irregularities	
Reentrant Corners: U shaped		Steps in Elevation View: 2 to 3 Changes	
None		None	
None		None	
Falling Hazards		Poor Conditions	
None		None	
None		None	
None		None	
			
W Vertical Irregularity Primary			

