

Blossom Gulch Elementary School

Coos_sch01A

Coos Bay SD 9

Building Type		County	
School		Coos	
Street			
333 S 10th St.			
City	State	Zip	
Coos Bay	OR	97420	
Latitude		Longitude	
43.36535		124.22331	
Tracking Code		Inspection Date	
RVS in 2006		8/14/2006	



Seismicity Zone: Very High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	3.8	-2	-0.5	0	0	-0.4	0	0	0.9
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Blossom Gulch Elementary School

Final RVS Score

Final Type

Final Score

W2

0.9

FEMA-154 Collapse Potential

High (>10%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
499		1954	1950
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
59896	2	No	No

Plan Irregularities	Vertical Irregularities
Reentrant Corners: Other	Steps in Elevation View: 2 to 3 Changes
None	None
None	None

Falling Hazards	Poor Conditions
None	None
None	None
None	None



W Plan Irregularity Primary



W Vertical Irregularity Primary



E Plan Irregularity Secondary

