

# Madison Elementary School

Coos Bay SD 9

Coos\_sch03A

Building Type	County	
School	Coos	
Street		
400 Maddison St		
City	State	Zip
Coos Bay	OR	97420
Latitude	Longitude	
43.3878	124.27326	
Tracking Code	Inspection Date	
RVS in 2006	8/18/2006	



Seismicity Zone: Very High

## FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	3.8	-2	-0.5	0	0	-0.4	0	0	0.9
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Madison Elementary School

## Final RVS Score

Final Type	Final Score
W2	0.9

## FEMA-154 Collapse Potential

High (>10%)



OregonGeology

# Madison Elementary School

Coos\_sch03A

Enrollment 396	Year Built (Field Verified) 1953	Year Built (Alt. Source) 1953	Est. Decade Built 1950
Total Area (square ft) 41809	Number of Stories 2	Basement	Pounding Potential No
<b>Plan Irregularities</b> Reentrant Corners: Other Reentrant Corners: Other (Adjacent Build/Entity) None		<b>Vertical Irregularities</b> Steps in Elevation View: 2 to 3 Changes Building On Hill or Sloped Site Steps in Elevation View: Single Change (Adjacent Building/Entity)	
<b>Falling Hazards</b> Unreinforced Chimneys None None		<b>Poor Conditions</b> None None None	
			
<b>SE</b> Falling Hazard The chimney has a big crack.		<b>W</b> Plan Irregularity Primary	
		<b>NE</b> Vertical Irregularity Secondary	
		<b>SW</b> Vertical Irregularity Primary	
		<b>E</b> Plan Irregularity Secondary	
		<b>E</b> Vertical Irregularity Tertiary	



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment  
 Oregon Department of Geology and Mineral Industries

# Madison Elementary School

Coos Bay SD 9

Coos\_sch03B

Building Type	County
School	Coos
Street	
400 Madison St	
City	State Zip
Coos Bay	OR 97420
Latitude	Longitude
43.38787	124.27312
Tracking Code	Inspection Date
RVS in 2006	8/18/2006



Seismicity Zone: Very High

## FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W1	4.4	-2.5	-0.5	0	2.4	0	0	0	3.8
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Madison Elementary School

## Final RVS Score

Final Type	Final Score
W1	3.8

## FEMA-154 Collapse Potential

Low (<1%)



OregonGeology

# Madison Elementary School

Coos\_sch03B

Enrollment 396	Year Built (Field Verified) 1953	Year Built (Alt. Source) 1953	Est. Decade Built 1980
Total Area (square ft) 41809	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities Reentrant Corners:Other (Adjacent Build/Entity) None None		Vertical Irregularities Steps in Elevation View: Single Change (Adjacent Building/Entity) None None	
Falling Hazards None None None		Poor Conditions None None None	
 NE Vertical Irregularity Primary			



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment  
Oregon Department of Geology and Mineral Industries