

# Sunset Middle School

Coos Bay SD 9

Coos\_sch04A

Building Type	County	
School	Coos	
Street		
245 S Cammann St		
City	State	Zip
Coos Bay	OR	97420
Latitude	Longitude	
43.38963	124.27343	
Tracking Code	Inspection Date	
RVS in 2006	8/18/2006	



Seismicity Zone: Very High

## FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	RM1	2.8	-1	-0.5	0	0	-0.4	0	0	0.9
Secondary	W2	3.8	-2	-0.5	0	2.4	-0.4	0	0	3.3
Tertiary		0	0	0	0	0	0	0	0	0

Sunset Middle School

## Final RVS Score

Final Type	Final Score
RM1	0.9

## FEMA-154 Collapse Potential

High (>10%)



OregonGeology

# Sunset Middle School

Coos\_sch04A

Enrollment 575	Year Built (Field Verified) 1993	Year Built (Alt. Source) 1993	Est. Decade Built 1990
Total Area (square ft) 94474	Number of Stories 2	Basement	Pounding Potential No
Plan Irregularities		Vertical Irregularities	
Reentrant Corners: Other		Steps in Elevation View: Very Irregular Changes	
Out of Plane Lateral-Force-Resistance Elements		Building On Hill or Sloped Site	
None		None	
Falling Hazards		Poor Conditions	
None		None	
None		None	
None		None	
			
SW General Site		SE Plan Irregularity Primary	
		SE Secondary Structural Type	
		W Vertical Irregularity Primary	
		NE Plan Irregularity Primary	
SE Vertical Irregularity Secondary			



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment  
Oregon Department of Geology and Mineral Industries

# Sunset Middle School

Coos Bay SD 9

Coos\_sch04B

Building Type School	County Coos	
Street 245 S Cammann St.		
City Coos Bay	State OR	Zip 97420
Latitude 43.38903	Longitude 124.27314	
Tracking Code RVS in 2006	Inspection Date 8/18/2006	



Seismicity Zone: Very High

## FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W1	4.4	-2.5	-0.5	0	2.4	0	0	0	3.8
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Sunset Middle School

## Final RVS Score

Final Type	Final Score
W1	3.8

## FEMA-154 Collapse Potential

Low (<1%)



# Sunset Middle School

Coos\_sch04B

Enrollment 575	Year Built (Field Verified) 1993	Year Built (Alt. Source) 1990	Est. Decade Built 1990
Total Area (square ft) 94474	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities Out of Plane Lateral-Force-Resistance Elements None None		Vertical Irregularities Steps in Elevation View: Single Change None None	
Falling Hazards None None None		Poor Conditions None None None	
 NW Vertical Irregularity Primary			



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment  
Oregon Department of Geology and Mineral Industries