

Hillcrest Elementary School

Coos_sch06A

North Bend SD 13

Building Type		County	
School		Coos	
Street			
1100 Maine St			
City		State	Zip
North Bend		OR	97459
Latitude		Longitude	
43.40256		124.22826	
Tracking Code		Inspection Date	
RVS in 2006		8/18/2006	



Seismicity Zone: Very High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	3.8	-2	-0.5	0	0	-0.4	0	0	0.9
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Hillcrest Elementary School

Final RVS Score

Final Type

Final Score

W2

0.9

FEMA-154 Collapse Potential

High (>10%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
495		1948	1940
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
39484	2	No	No

Plan Irregularities	Vertical Irregularities
Reentrant Corners: Other (Adjacent Build/Entity)	Building On Hill or Sloped Site
Reentrant Corners: Other	Steps in Elevation View: Single Change (Adjacent Building/Entity)
None	None

Falling Hazards	Poor Conditions
None	None
None	None
None	None



N Plan Irregularity Secondary



N Vertical Irregularity Primary



N Vertical Irregularity Secondary



Hillcrest Elementary School

Coos_sch06B

North Bend SD 13

Building Type		County	
School		Coos	
Street			
1100 Maine St			
City	State	Zip	
North Bend	OR	97459	
Latitude		Longitude	
43.40254		124.22914	
Tracking Code		Inspection Date	
RVS in 2006		8/18/2006	



Seismicity Zone: Very High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	RM1	2.8	-1	-0.5	0	0	-0.4	0	0	0.9
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Hillcrest Elementary School

Final RVS Score

Final Type

Final Score

RM1

0.9

FEMA-154 Collapse Potential

High (>10%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
495		1948	1950
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
39484	1	No	No

Plan Irregularities	Vertical Irregularities
Out of Plane Lateral-Force-Resistance Elements	Steps in Elevation View: Single Change
None	Steps in Elevation View: Single Change (Adjacent Building/Entity)
None	None

Falling Hazards	Poor Conditions
None	None
None	None
None	None



W Vertical Irregularity Primary



S General Site

