

North Bay Elementary School

North Bend SD 13

Coos_sch07A

Building Type	County
School	Coos
Street	
93670 Viking Way	
City	State Zip
North Bend	OR 97459
Latitude	Longitude
43.50143	124.21077
Tracking Code	Inspection Date
RVS in 2006	8/18/2006



Seismicity Zone: Very High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	RM1	2.8	-1	-0.5	0	0	0	-0.6	0	0.7
Secondary	W2	3.8	-2	-0.5	0	0	0	-0.8	0	0.5
Tertiary		0	0	0	0	0	0	0	0	0

North Bay Elementary School

Final RVS Score

Final Type

W2

Final Score

0.5

FEMA-154 Collapse Potential

High (>10%)



OregonGeology

North Bay Elementary School

Coos_sch07A

Enrollment 170	Year Built (Field Verified) 1967	Year Built (Alt. Source) 1967	Est. Decade Built 1960
Total Area (square ft) 77235	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities		Vertical Irregularities	
Reentrant Corners: Other		Steps in Elevation View: 2 to 3 Changes	
Out of Plane Lateral-Force-Resistance Elements		None	
Large Diaphragm or Central Opening		None	
Falling Hazards		Poor Conditions	
None		None	
None		None	
None		None	
			
E	Plan Irregularity Secondary	E	Vertical Irregularity Primary
			
S	Plan Irregularity Primary		
			
NW	Secondary Structural Type	W	Plan Irregularity Tertiary



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries