

North Bend Middle School

North Bend SD 13

Coos_sch08A

Building Type	County	
School	Coos	
Street		
1500 16th St		
City	State	Zip
North Bend	OR	97459
Latitude	Longitude	
43.39879	124.23268	
Tracking Code	Inspection Date	
RVS in 2006	8/18/2006	



Seismicity Zone: Very High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	RM1	2.8	-1	-0.5	0	0	0	-0.6	0	0.7
Secondary	S3	3.2	0	-0.5	0	0	0	-0.6	0	2.1
Tertiary		0	0	0	0	0	0	0	0	0

North Bend Middle School

Final RVS Score

Final Type

RM1

Final Score

0.7

FEMA-154 Collapse Potential

High (>10%)



OregonGeology

North Bend Middle School

Coos_sch08A

Enrollment 386	Year Built (Field Verified) 1960	Year Built (Alt. Source) 1960	Est. Decade Built 1960
Total Area (square ft) 86186	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities		Vertical Irregularities	
Reentrant Corners: Other		Steps in Elevation View: 2 to 3 Changes	
Reentrant Corners: Other (Adjacent Build/Entity)		None	
Out of Plane Lateral-Force-Resistance Elements		None	
Falling Hazards		Poor Conditions	
None		None	
None		None	
None		None	
			
NE General Site S3 on the top and RM1 on the bottom.		E Vertical Irregularity Primary	
		E Plan Irregularity Secondary	
			
W Plan Irregularity Secondary		E Secondary Structural Type	



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

North Bend Middle School

North Bend SD 13

Coos_sch08B

Building Type	County
School	Coos
Street	
1500 16th St	
City	State Zip
North Bend	OR 97459
Latitude	Longitude
43.39846	124.23306
Tracking Code	Inspection Date
RVS in 2006	8/18/2006



Seismicity Zone: Very High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	RM1	2.8	-1	-0.5	0	0	0	-0.6	0	0.7
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

North Bend Middle School

Final RVS Score

Final Type	Final Score
RM1	0.7

FEMA-154 Collapse Potential

High (>10%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

North Bend Middle School

Coos_sch08B

Enrollment 386	Year Built (Field Verified) 1960	Year Built (Alt. Source) 1960	Est. Decade Built 1970
Total Area (square ft) 86186	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities		Vertical Irregularities	
Reentrant Corners: Other		Steps in Elevation View: Single Change	
Reentrant Corners: U shaped		None	
None		None	
Falling Hazards		Poor Conditions	
None		None	
None		None	
None		None	
			
S	Plan Irregularity Primary	W	Plan Irregularity Secondary



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries