

Millicoma Intermediate School

Coos Bay SD 9

Coos_sch21A

Building Type	County
School	Coos
Street	
260 2nd Ave.	
City	State Zip
Coos Bay	OR 97420
Latitude	Longitude
43.36624	124.19702
Tracking Code	Inspection Date
RVS in 2006	8/14/2006



Seismicity Zone: Very High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	3.8	-2	-0.5	0	0	0	-0.8	0	0.5
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Millicoma Intermediate School

Final RVS Score

Final Type	Final Score
W2	0.5

FEMA-154 Collapse Potential

High (>10%)



OregonGeology

Millicoma Intermediate School

Coos_sch21A

Enrollment 486	Year Built (Field Verified) 1962	Year Built (Alt. Source) 1962	Est. Decade Built 1960
Total Area (square ft) 81767	Number of Stories 3	Basement	Pounding Potential No
Plan Irregularities		Vertical Irregularities	
Reentrant Corners:Other (Adjacent Build/Entity)		Building On Hill or Sloped Site	
Out of Plane Lateral-Force-Resistance Elements		None	
Reentrant Corners: Other		None	
Falling Hazards		Poor Conditions	
None		None	
None		None	
None		None	
			
N Plan Irregularity Tertiary		W Plan Irregularity Secondary	
		SE Vertical Irregularity Primary	
		E Plan Irregularity Primary	



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Millicoma Intermediate School

Coos Bay SD 9

Coos_sch21B

Building Type	County	
School	Coos	
Street		
260 2nd Ave.		
City	State	Zip
Coos Bay	OR	97420
Latitude	Longitude	
43.36657	124.19726	
Tracking Code	Inspection Date	
RVS in 2006	8/14/2006	



Seismicity Zone: Very High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W1	4.4	0	-0.5	0	2.4	0	0	0	6.3
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Millicoma Intermediate School

Final RVS Score

Final Type	Final Score
W1	6.3

FEMA-154 Collapse Potential

Low (<1%)



OregonGeology

Millicoma Intermediate School

Coos_sch21B

Enrollment 486	Year Built (Field Verified) 1962	Year Built (Alt. Source) 1962	Est. Decade Built 1980
Total Area (square ft) 81767	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities		Vertical Irregularities	
Out of Plane Lateral-Force-Resistance Elements		None	
Reentrant Corners: Other		None	
None		None	
Falling Hazards		Poor Conditions	
None		None	
None		None	
None		None	
			
NW Plan Irregularity Secondary			



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Millicoma Intermediate School

Coos Bay SD 9

Coos_sch21D

Building Type	County	
School	Coos	
Street		
260 2nd Ave.		
City	State	Zip
Coos Bay	OR	97420
Latitude	Longitude	
43.36673	124.19664	
Tracking Code	Inspection Date	
RVS in 2006	8/30/2006	



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	3.8	-2	-0.5	0	0	0	-0.8	0	0.5
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Millicoma Intermediate School

Final RVS Score

Final Type	Final Score
W2	0.5

FEMA-154 Collapse Potential

High (>10%)



OregonGeology

Millicoma Intermediate School

Coos_sch21D

Enrollment 486	Year Built (Field Verified) 1962	Year Built (Alt. Source) 1962	Est. Decade Built 1970
Total Area (square ft) 81767	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities Reentrant Corners: Other None None		Vertical Irregularities Steps in Elevation View: 2 to 3 Changes None None	
Falling Hazards None None None		Poor Conditions None None None	
			
NE Vertical Irregularity Primary		N Vertical Irregularity Primary	



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries