

Coquille High School

Coquille SD 8

Coos_sch24A

Building Type	County	
School	Coos	
Street		
499 W Central Blvd.		
City	State	Zip
Coquille	OR	97423
Latitude	Longitude	
43.18534	124.19408	
Tracking Code	Inspection Date	
RVS in 2006	8/10/2006	



Seismicity Zone: Very High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	C2	2.8	-1	-0.5	0	0	-0.4	0	0	0.9
Secondary	RM1	2.8	-1	-0.5	0	0	-0.4	0	0	0.9
Tertiary	C1	2.5	-1.5	-0.5	0	0	-0.4	0	0	0.1

Coquille High School

Final RVS Score

Final Type	Final Score
C1	0.1

FEMA-154 Collapse Potential

High (>10%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Coquille High School

Coos_sch24A

Enrollment 371	Year Built (Field Verified) 1949	Year Built (Alt. Source) 1940	Est. Decade Built 1940
Total Area (square ft) 106102	Number of Stories 2	Basement	Pounding Potential No
Plan Irregularities		Vertical Irregularities	
Reentrant Corners: Other		Steps in Elevation View: Very Irregular Changes	
Non-Parallel System		Building On Hill or Sloped Site	
Reentrant Corners: Other (Adjacent Build/Entity)		Steps in Elevation View: 2 to 3 Changes (Adjacent Building/Entity)	
Falling Hazards		Poor Conditions	
Unreinforced Chimneys		Cracks	
None		None	
None		None	
			
W Vertical Irregularity Primary		W Vertical Irregularity Tertiary	
		S Poor Condition All over the gym.	
			
E Plan Irregularity Secondary This is very small compared to the size of the building.		E Vertical Irregularity Secondary	
		N Falling Hazard	
		NE Plan Irregularity Tertiary	



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Coquille High School

Coquille SD 8

Coos_sch24B

Building Type	County
School	Coos
Street	
499 W Central Blvd.	
City	State Zip
Coquille	OR 97423
Latitude	Longitude
43.18601	124.19455
Tracking Code	Inspection Date
RVS in 2006	8/10/2006



Seismicity Zone: Very High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	3.8	-2	-0.5	0	0	-0.4	0	0	0.9
Secondary	RM1	2.8	-1	-0.5	0	0	-0.4	0	0	0.9
Tertiary		0	0	0	0	0	0	0	0	0

Coquille High School

Final RVS Score

Final Type	Final Score
W2	0.9

FEMA-154 Collapse Potential

High (>10%)



Coquille High School

Coos_sch24B

Enrollment 371	Year Built (Field Verified) 1949	Year Built (Alt. Source) 1949	Est. Decade Built 1970
Total Area (square ft) 106102	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities		Vertical Irregularities	
Reentrant Corners: Other		Steps in Elevation View: Single Change (Adjacent Building/Entity)	
Reentrant Corners: Other (Adjacent Build/Entity)		None	
Non-Parallel System		None	
Falling Hazards		Poor Conditions	
None		None	
None		None	
None		None	
			
W General Site		NE Vertical Irregularity Primary	
		NE Plan Irregularity Secondary	



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries