

# Powers Elementary School

Powers SD 31

Coos\_sch26A

Building Type	County
School	Coos
Street	
4th and Poplar	
City	State Zip
Powers	OR 97466
Latitude	Longitude
42.88065	124.06803
Tracking Code	Inspection Date
RVS in 2006	8/10/2006



Seismicity Zone: Very High

## FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W1	4.4	0	-0.5	0	0	0	0	0	3.9
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Powers Elementary School

## Final RVS Score

Final Type	Final Score
W1	3.9

## FEMA-154 Collapse Potential

Low (<1%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment  
Oregon Department of Geology and Mineral Industries

# Powers Elementary School

Coos\_sch26A

Enrollment 72	Year Built (Field Verified) 1930	Year Built (Alt. Source) 1930	Est. Decade Built 1930
Total Area (square ft) 8635	Number of Stories 2	Basement	Pounding Potential No
Plan Irregularities Out of Plane Lateral-Force-Resistance Elements None None		Vertical Irregularities None None None	
Falling Hazards None None None		Poor Conditions None None None	
 NE General Site			



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment  
Oregon Department of Geology and Mineral Industries

# Powers Elementary School

Powers SD 31

Coos\_sch26B

Building Type	County	
School	Coos	
Street		
4th and Poplar		
City	State	Zip
Powers	OR	97466
Latitude	Longitude	
42.88107	124.06856	
Tracking Code	Inspection Date	
RVS in 2006	8/10/2006	



Seismicity Zone: Very High

## FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	S3	3.2	0	0	0	0	-0.4	0	0	2.8
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Powers Elementary School

## Final RVS Score

Final Type	Final Score
S3	2.8

## FEMA-154 Collapse Potential

Low (<1%)



OregonGeology

# Powers Elementary School

Coos\_sch26B

Enrollment 72	Year Built (Field Verified) 1930	Year Built (Alt. Source) 1930	Est. Decade Built 1960
Total Area (square ft) 8635	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities None None None		Vertical Irregularities None None None	
Falling Hazards None None None		Poor Conditions None None None	