

Cecil Sly Elementary School

Crook County SD

Croo_sch02A

| | | | |
|----------------|-------|-----------------|--|
| Building Type | | County | |
| School | | Crook | |
| Street | | | |
| 1400 SE 2nd St | | | |
| City | State | Zip | |
| Prineville | OR | 97754 | |
| Latitude | | Longitude | |
| 44.29959 | | 120.82991 | |
| Tracking Code | | Inspection Date | |
| RVS in 2006 | | 7/6/2006 | |



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

| | Type | Basic Score | Vert Irreg | Plan Irreg | Pre-Code | Post-Bench | Soil C | Soil D | Soil E | RVS Score |
|-----------|------|-------------|------------|------------|----------|------------|--------|--------|--------|-----------|
| Primary | W2 | 4.8 | -3 | -0.5 | 0 | 0 | 0 | -1.2 | 0 | 0.1 |
| Secondary | C2 | 3.6 | -2 | -0.5 | 0 | 0 | 0 | -1.2 | 0 | -0.1 |
| Tertiary | RM1 | 3.6 | -2 | -0.5 | 0 | 0 | 0 | -1.2 | 0 | -0.1 |

Cecil Sly Elementary School

Final RVS Score

Final Type

Final Score

C2

-0.1

FEMA-154 Collapse Potential

Very High (100%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

| | | | |
|------------------------|-----------------------------|--------------------------|--------------------|
| Enrollment | Year Built (Field Verified) | Year Built (Alt. Source) | Est. Decade Built |
| 515 | | 1937 | 1960 |
| Total Area (square ft) | Number of Stories | Basement | Pounding Potential |
| 57730 | 1 | No | No |

| | |
|-----------------------------|--|
| Plan Irregularities | Vertical Irregularities |
| Reentrant Corners: L Shaped | Steps in Elevation View: Single Change |
| None | None |
| None | None |

| | |
|-----------------|-----------------|
| Falling Hazards | Poor Conditions |
| None | None |
| None | None |
| None | None |



NW General Site



NE General Site



W Plan Irregularity Primary



Cecil Sly Elementary School

Crook County SD

Croo_sch02B

| | | | |
|----------------|-------|-----------------|--|
| Building Type | | County | |
| School | | Crook | |
| Street | | | |
| 1400 SE 2nd St | | | |
| City | State | Zip | |
| Prineville | OR | 97754 | |
| Latitude | | Longitude | |
| 44.29953 | | 120.82912 | |
| Tracking Code | | Inspection Date | |
| RVS in 2006 | | 7/6/2006 | |



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

| | Type | Basic Score | Vert Irreg | Plan Irreg | Pre-Code | Post-Bench | Soil C | Soil D | Soil E | RVS Score |
|-----------|------|-------------|------------|------------|----------|------------|--------|--------|--------|-----------|
| Primary | W2 | 4.8 | 0 | -0.5 | 0 | 0 | 0 | -1.2 | 0 | 3.1 |
| Secondary | RM1 | 3.6 | 0 | -0.5 | 0 | 0 | 0 | -1.2 | 0 | 1.9 |
| Tertiary | C2 | 3.6 | 0 | -0.5 | 0 | 0 | 0 | -1.2 | 0 | 1.9 |

Cecil Sly Elementary School

Final RVS Score

Final Type

Final Score

RM1

1.9

FEMA-154 Collapse Potential

Moderate (>1%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

| | | | |
|------------------------|-----------------------------|--------------------------|--------------------|
| Enrollment | Year Built (Field Verified) | Year Built (Alt. Source) | Est. Decade Built |
| 515 | | 1937 | 1970 |
| Total Area (square ft) | Number of Stories | Basement | Pounding Potential |
| 57730 | 1 | No | No |

| | |
|--|-------------------------|
| Plan Irregularities | Vertical Irregularities |
| Reentrant Corners:T shaped (Adjacent Build/Entity) | None |
| None | None |
| None | None |

| | |
|-----------------|-----------------|
| Falling Hazards | Poor Conditions |
| None | None |
| None | None |
| None | None |



SE General Site

Cecil Sly Elementary School

Crook County SD

Croo_sch02C

| | | | |
|----------------|-------|-----------------|--|
| Building Type | | County | |
| School | | Crook | |
| Street | | | |
| 1400 SE 2nd St | | | |
| City | State | Zip | |
| Prineville | OR | 97754 | |
| Latitude | | Longitude | |
| 44.29927 | | 120.83035 | |
| Tracking Code | | Inspection Date | |
| RVS in 2006 | | 7/6/2006 | |



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

| | Type | Basic Score | Vert Irreg | Plan Irreg | Pre-Code | Post-Bench | Soil C | Soil D | Soil E | RVS Score |
|-----------|------|-------------|------------|------------|----------|------------|--------|--------|--------|-----------|
| Primary | W1 | 5.2 | 0 | 0 | 0 | 0 | 0 | -0.6 | 0 | 4.6 |
| Secondary | RM1 | 3.6 | 0 | 0 | 0 | 0 | 0 | -1.2 | 0 | 2.4 |
| Tertiary | | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |

Cecil Sly Elementary School

Final RVS Score

Final Type

Final Score

RM1

2.4

FEMA-154 Collapse Potential

Low (<1%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

| | | | |
|------------------------|-----------------------------|--------------------------|--------------------|
| Enrollment | Year Built (Field Verified) | Year Built (Alt. Source) | Est. Decade Built |
| 515 | | 1937 | 1970 |
| Total Area (square ft) | Number of Stories | Basement | Pounding Potential |
| 57730 | 1 | No | No |

| | |
|---------------------|-------------------------|
| Plan Irregularities | Vertical Irregularities |
| None | None |
| None | None |
| None | None |

| | |
|-----------------|-----------------|
| Falling Hazards | Poor Conditions |
| None | None |
| None | None |
| None | None |

