

Crooked River Elementary School

Crook County SD

Croo_sch03A

Building Type	County	
School	Crook	
Street		
641 E 1st St		
City	State	Zip
Prineville	OR	97754
Latitude	Longitude	
44.30148	120.84044	
Tracking Code	Inspection Date	
RVS in 2006	7/6/2006	



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	C2	3.6	-2	-0.5	-0.4	0	0	-1.2	0	-0.5
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Crooked River Elementary School

Final RVS Score

Final Type

Final Score

C2

-0.5

FEMA-154 Collapse Potential

Very High (100%)



Crooked River Elementary School

Croo_sch03A

Enrollment 390	Year Built (Field Verified) 1939	Year Built (Alt. Source) 1939	Est. Decade Built 1930
Total Area (square ft) 42043	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities		Vertical Irregularities	
Reentrant Corners: L Shaped		Steps in Elevation View: 2 to 3 Changes	
Reentrant Corners: Other		Steps in Elevation View: Single Change (Adjacent Building/Entity)	
None		None	
Falling Hazards		Poor Conditions	
None		None	
None		None	
None		None	
			
N Plan Irregularity Primary		NW Vertical Irregularity Primary	
		N Building Name	



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Crooked River Elementary School

Crook County SD

Croo_sch03B

Building Type	County	
School	Crook	
Street		
641 E 1st St		
City	State	Zip
Prineville	OR	97754
Latitude	Longitude	
44.30256	120.84041	
Tracking Code	Inspection Date	
RVS in 2006	7/6/2006	



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	C2	3.6	0	-0.5	-0.4	0	0	-1.2	0	1.5
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Crooked River Elementary School

Final RVS Score

Final Type	Final Score
C2	1.5

FEMA-154 Collapse Potential

Moderate (>1%)



OregonGeology

Crooked River Elementary School

Croo_sch03B

Enrollment 390	Year Built (Field Verified) 1939	Year Built (Alt. Source) 1939	Est. Decade Built 1930
Total Area (square ft) 42043	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities Reentrant Corners: L Shaped None None		Vertical Irregularities None None None	
Falling Hazards Other: Smokestack None None		Poor Conditions None None None	
			
SW Plan Irregularity Primary		NE General Site	
			
		N Elevation View	

Crooked River Elementary School

Crook County SD

Croo_sch03C

Building Type	County	
School	Crook	
Street		
641 E 1st St		
City	State	Zip
Prineville	OR	97754
Latitude	Longitude	
44.30205	120.84022	
Tracking Code	Inspection Date	
RVS in 2006	7/6/2006	



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	RM1	3.6	-2	0	0	0	0	-1.2	0	0.4
Secondary	C2	3.6	-2	0	0	0	0	-1.2	0	0.4
Tertiary	W1	5.2	-3.5	0	0	0	0	-0.6	0	1.1

Crooked River Elementary School

Final RVS Score

Final Type	Final Score
RM1	0.4

FEMA-154 Collapse Potential

High (>10%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Crooked River Elementary School

Croo_sch03C

Enrollment 390	Year Built (Field Verified) 1939	Year Built (Alt. Source) 1939	Est. Decade Built 1950
Total Area (square ft) 42043	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities None None None		Vertical Irregularities Steps in Elevation View: Single Change None None	
Falling Hazards None None None		Poor Conditions None None None	

Crooked River Elementary School

Crook County SD

Croo_sch03D

Building Type	County	
School	Crook	
Street		
641 E 1st St		
City	State	Zip
Prineville	OR	97754
Latitude	Longitude	
44.30158	120.84042	
Tracking Code	Inspection Date	
RVS in 2006	7/6/2006	



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	RM1	3.6	-2	-0.5	0	0	0	-1.2	0	-0.1
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Crooked River Elementary School

Final RVS Score

Final Type	Final Score
RM1	-0.1

FEMA-154 Collapse Potential

Very High (100%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Crooked River Elementary School

Croo_sch03D

Enrollment 390	Year Built (Field Verified) 1939	Year Built (Alt. Source) 1939	Est. Decade Built 1980
Total Area (square ft) 42043	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities Reentrant Corners:T shaped (Adjacent Build/Entity) None None		Vertical Irregularities Steps in Elevation View: Single Change (Adjacent Building/Entity) None None	
Falling Hazards None None None		Poor Conditions None None None	