

Port Orford Police Dept and Rural Fire Dist

City of Port Orford

Curr_fir01A

Building Type	County
Fire - City	Curry
Street	
555 W 20th St.	
City	State Zip
Port Orford	OR 97465
Latitude	Longitude
42.75394	124.49855
Tracking Code	Inspection Date
RVS in 2006	8/4/2006



Seismicity Zone: Very High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	RM1	2.8	-1	-0.5	0	0	0	-0.6	0	0.7
Secondary	W2	3.8	-2	-0.5	0	0	0	-0.8	0	0.5
Tertiary		0	0	0	0	0	0	0	0	0

Port Orford Police Dept and Rural Fire Dist

Final RVS Score

Final Type	Final Score
W2	0.5

FEMA-154 Collapse Potential

High (>10%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Port Orford Police Dept and Rural Fire Dist

Curr_fir01A

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
			1960
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
	1	No	No
Plan Irregularities		Vertical Irregularities	
Reentrant Corners: Other		Steps in Elevation View: 2 to 3 Changes	
Out of Plane Lateral-Force-Resistance Elements		None	
None		None	
Falling Hazards		Poor Conditions	
None		None	
None		None	
None		None	
			
W	Vertical Irregularity Primary	S	Secondary Structural Type
			
W	Plan Irregularity Secondary	S	Plan Irregularity Primary



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries