

Ophir RFPD

Ophir RFPD

Curr_fir08A

Building Type Fire - RFPD	County Curry	
Street 32888 Nesika Road		
City Gold Beach	State OR	Zip 97444
Latitude 42.50183	Longitude 124.41505	
Tracking Code RVS in 2006	Inspection Date 8/4/2006	



Seismicity Zone: Very High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	RM1	2.8	-1	0	0	0	0	-0.6	0	1.2
Secondary	W2	3.8	-2	0	0	0	0	-0.8	0	1
Tertiary		0	0	0	0	0	0	0	0	0

Ophir RFPD

Final RVS Score

Final Type	Final Score
W2	1

FEMA-154 Collapse Potential

High (>10%)



OregonGeology

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
			1950
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
	1	No	No
Plan Irregularities		Vertical Irregularities	
None		Steps in Elevation View: 2 to 3 Changes	
None		None	
None		None	
Falling Hazards		Poor Conditions	
None		None	
None		None	
None		None	
			
SW Vertical Irregularity Primary			

