

# Upper Chetco RFPD

Curr\_fir12A

Upper Chetco RFPD

|                          |                 |        |  |
|--------------------------|-----------------|--------|--|
| Building Type            |                 | County |  |
| Fire - RFPD              |                 | Curry  |  |
| Street                   |                 |        |  |
| 17548 Gardiner Ridge Rd. |                 |        |  |
| City                     | State           | Zip    |  |
| Brookings                | OR              | 97415  |  |
| Latitude                 | Longitude       |        |  |
| 42.0866                  | 124.20489       |        |  |
| Tracking Code            | Inspection Date |        |  |
| RVS in 2006              | 8/4/2006        |        |  |



Seismicity Zone: Very High

## FEMA 154 Rapid Visual Screening Score Card

|           | Type | Basic Score | Vert Irreg | Plan Irreg | Pre-Code | Post-Bench | Soil C | Soil D | Soil E | RVS Score |
|-----------|------|-------------|------------|------------|----------|------------|--------|--------|--------|-----------|
| Primary   | W1   | 4.4         | 0          | -0.5       | 0        | 2.4        | 0      | 0      | 0      | 6.3       |
| Secondary |      | 0           | 0          | 0          | 0        | 0          | 0      | 0      | 0      | 0         |
| Tertiary  |      | 0           | 0          | 0          | 0        | 0          | 0      | 0      | 0      | 0         |

Upper Chetco RFPD

## Final RVS Score

Final Type

Final Score

W1

6.3

## FEMA-154 Collapse Potential

Low (<1%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment  
Oregon Department of Geology and Mineral Industries

|                        |                             |                          |                    |
|------------------------|-----------------------------|--------------------------|--------------------|
| Enrollment             | Year Built (Field Verified) | Year Built (Alt. Source) | Est. Decade Built  |
|                        | 1982                        | 1982                     | 1980               |
| Total Area (square ft) | Number of Stories           | Basement                 | Pounding Potential |
|                        | 1                           | No                       | No                 |

|                              |                         |
|------------------------------|-------------------------|
| Plan Irregularities          | Vertical Irregularities |
| Torsion: Eccentric Stiffness | None                    |
| None                         | None                    |
| None                         | None                    |

|                 |                 |
|-----------------|-----------------|
| Falling Hazards | Poor Conditions |
| None            | None            |
| None            | None            |
| None            | None            |



SW General Site



N Field Verified Year Built