

Azalea Middle School

Brookings-Harbor SD 17C

Curr_sch02A

Building Type		County	
School		Curry	
Street			
505 Pacific Ave.			
City	State	Zip	
Brookings	OR	97415	
Latitude		Longitude	
42.05558		124.2812	
Tracking Code		Inspection Date	
RVS in 2006		8/4/2006	



Seismicity Zone: Very High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	3.8	-2	-0.5	0	0	0	0	0	1.3
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Azalea Middle School

Final RVS Score

Final Type

Final Score

W2

1.3

FEMA-154 Collapse Potential

Moderate (>1%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
414		1950	1950
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
62599	1	No	No

Plan Irregularities	Vertical Irregularities
Reentrant Corners: L Shaped	Steps in Elevation View: 2 to 3 Changes
Non-Parallel System	Steps in Elevation View: Single Change (Adjacent Building/Entity)
Reentrant Corners: Other (Adjacent Build/Entity)	None

Falling Hazards	Poor Conditions
None	None
None	None
None	None



S Plan Irregularity Secondary



N Plan Irregularity Primary



N Vertical Irregularity Primary



S Vertical Irregularity Secondary



N Plan Irregularity Tertiary



Azalea Middle School

Brookings-Harbor SD 17C

Curr_sch02B

Building Type		County	
School		Curry	
Street			
505 Pacific Ave.			
City	State	Zip	
Brookings	OR	97415	
Latitude		Longitude	
42.05516		124.28169	
Tracking Code		Inspection Date	
RVS in 2006		8/4/2006	



Seismicity Zone: Very High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W1	4.4	0	-0.5	0	2.4	0	0	0	6.3
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Azalea Middle School

Final RVS Score

Final Type

Final Score

W1

6.3

FEMA-154 Collapse Potential

Low (<1%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
414		1950	1980
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
62599	1	No	No

Plan Irregularities	Vertical Irregularities
Reentrant Corners: Other	Steps in Elevation View: Single Change (Adjacent Building/Entity)
Reentrant Corners: Other (Adjacent Build/Entity)	None
None	None

Falling Hazards	Poor Conditions
None	None
None	None
None	None



N Plan Irregularity Secondary



S Vertical Irregularity Primary



Azalea Middle School

Brookings-Harbor SD 17C

Curr_sch02C

Building Type		County	
School		Curry	
Street			
505 Pacific Ave.			
City	State	Zip	
Brookings	OR	97415	
Latitude		Longitude	
42.05648		124.28121	
Tracking Code		Inspection Date	
RVS in 2006		8/4/2006	



Seismicity Zone: Very High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	3.8	-2	-0.5	0	0	0	0	0	1.3
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Azalea Middle School

Final RVS Score

Final Type

Final Score

W2

1.3

FEMA-154 Collapse Potential

Moderate (>1%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
414		1950	1950
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
62599	1	No	No

Plan Irregularities	Vertical Irregularities
Reentrant Corners: L Shaped	Steps in Elevation View: Very Irregular Changes
Out of Plane Lateral-Force-Resistance Elements	None
None	None

Falling Hazards	Poor Conditions
None	None
None	None
None	None



W Plan Irregularity Primary



W Plan Irregularity Secondary



S Vertical Irregularity Primary



E General Site

