

Upper Chetco Charter School

Brookings-Harbor SD 17C

Curr_sch11A

Building Type	County
School	Curry
Street	
99603 North Band Chetco River Rd	
City	State Zip
Brookings	OR 97415
Latitude	Longitude
42.08137	124.20036
Tracking Code	Inspection Date
RVS in 2006	8/4/2006



Seismicity Zone: Very High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	3.8	-2	-0.5	-1	0	-0.4	0	0	-0.1
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Upper Chetco Charter School

Final RVS Score

Final Type	Final Score
W2	-0.1

FEMA-154 Collapse Potential

Very High (100%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Upper Chetco Charter School

Curr_sch11A

Enrollment 27	Year Built (Field Verified) 1938	Year Built (Alt. Source) 1930	Est. Decade Built 1930
Total Area (square ft) 7749	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities		Vertical Irregularities	
Reentrant Corners: L Shaped		Steps in Elevation View: 2 to 3 Changes	
Out of Plane Lateral-Force-Resistance Elements		None	
None		None	
Falling Hazards		Poor Conditions	
None		None	
None		None	
None		None	
			
E	Vertical Irregularity Primary	W	Plan Irregularity Primary
			
		W	Plan Irregularity Secondary



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Upper Chetco Charter School

Brookings-Harbor SD 17C

Curr_sch11C

Building Type	County
School	Curry
Street	
99603 North Band Chetco River Rd	
City	State Zip
Brookings	OR 97415
Latitude	Longitude
42.08153	124.20067
Tracking Code	Inspection Date
RVS in 2006	8/4/2006



Seismicity Zone: Very High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	3.8	-2	-0.5	0	0	-0.4	0	0	0.9
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Upper Chetco Charter School

Final RVS Score

Final Type

W2

Final Score

0.9

FEMA-154 Collapse Potential

High (>10%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Upper Chetco Charter School

Curr_sch11C

Enrollment 27	Year Built (Field Verified) 1938	Year Built (Alt. Source) 1960	Est. Decade Built
Total Area (square ft) 7749	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities Out of Plane Lateral-Force-Resistance Elements None None		Vertical Irregularities Steps in Elevation View: Single Change None None	
Falling Hazards None None None		Poor Conditions None None None	
 SE Plan Irregularity Primary			



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries