

Central Oregon CC

Building Type Community_College	County Deschutes	
Street 2600 NW College Way		
City Bend	State OR	Zip 97701
Latitude 44.07031	Longitude 121.34565	
Tracking Code Miller 2004-05	Inspection Date 8/26/2005	

Seismicity Zone: Moderate

## FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	RM1	3.6	-2	-0.5	0	0	0	0	0	1.1
Secondary	C1	3	-2	-0.5	0	0	0	0	0	0.5
Tertiary	C2	3.6	-2	-0.5	0	0	0	0	0	1.1


Pinckney Arts Ctr.

## Final RVS Score

Final Type	Final Score
C1	0.5

## FEMA-154 Collapse Potential

High (&gt;10%)



Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
	1983	1983	1980
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
14931	2	Yes	No
Plan Irregularities		Vertical Irregularities	
Yes: Unknown		Yes: Unknown	
Falling Hazards		Poor Conditions	
None			
None			
None			