

Grandview Student Union Center

Central Oregon CC

Desc_coc03A

Building Type		County	
Community_College		Deschutes	
Street			
2600 NW College Way			
City	State	Zip	
Bend	OR	97701	
Latitude		Longitude	
44.071		121.34484	
Tracking Code		Inspection Date	
Miller 2004-05		3/1/2007	

Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	C1	3	-2	-0.5	0	0	0	0	0	0.5
Secondary	C2	3.6	-2	-0.5	0	0	0	0	0	1.1
Tertiary		0	0	0	0	0	0	0	0	0

Grandview Student Union Center

Final RVS Score

Final Type

Final Score

C1


0.5

FEMA-154 Collapse Potential

High (>10%)

CENTRAL OREGON COMMUNITY COLLEGE

Bend, Oregon 97701 • (541) 383-7700



Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
	1964	1964	1960
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
25722	2	No	No

Plan Irregularities	Vertical Irregularities
Yes: Unknown	Yes: Unknown

Falling Hazards	Poor Conditions
None	
None	