

## Modoc (Old Library)

## Desc\_coc05A

Central Oregon CC

Building Type	County	
Community_College	Deschutes	
Street		
2600 NW College Way		
City	State	Zip
Bend	OR	97701
Latitude	Longitude	
44.07115	121.34635	
Tracking Code	Inspection Date	
Miller 2004-05	8/26/2005	

### Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card


## Modoc (Old Library)

## Final RVS Score

Final Type	Final Score
C1	0.5

## FEMA-154 Collapse Potential

High (>10%)



# OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment  
Oregon Department of Geology and Mineral Industries

# Modoc (Old Library)

Desc\_coc05A

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
	1966	1966	1960
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
16389	2	No	No
Plan Irregularities		Vertical Irregularities	
Yes: Unknown		None	
Falling Hazards		Poor Conditions	
None			
None			
None			