

Central Oregon CC

Building Type Community_College	County Deschutes	
Street 2600 NW College Way		
City Bend	State OR	Zip 97701
Latitude 44.0691	Longitude 121.34815	
Tracking Code Miller 2004-05	Inspection Date 8/26/2005	

Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	RM1	3.6	-2	-0.5	0	0	0	0	0	1.1
Secondary	RM2	3.4	-1.5	-1.5	0	0	0	0	0	0.4
Tertiary	C2	3.6	-2	-0.5	0	0	0	0	0	1.1


Ponderosa

Final RVS Score

Final Type	Final Score
RM2	0.4

FEMA-154 Collapse Potential

High (>10%)



OregonGeology

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
	1971	1971	1970
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
31334	2	Yes	No
Plan Irregularities		Vertical Irregularities	
Yes: Unknown		Yes: Unknown	
Falling Hazards		Poor Conditions	
None			
None			
None			

