

Black Butte RFPD

Desc_fir01A

Black Butte RFPD

Building Type	County	
Fire - RFPD	Deschutes	
Street		
13511 Hawks Beard		
City	State	Zip
Sisters	OR	97759
Latitude	Longitude	
44.3793	121.66295	
Tracking Code	Inspection Date	
RVS in 2006	6/27/2006	



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W1	5.2	-3.5	0	0	1.6	-0.2	0	0	3.1
Secondary	RM1	3.6	-2	0	0	0	-0.8	0	0	0.8
Tertiary		0	0	0	0	0	0	0	0	0

Black Butte RFPD

Final RVS Score

Final Type	Final Score
RM1	0.8

FEMA-154 Collapse Potential

High (>10%)



OregonGeology

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
		1980	1980
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
	2	No	No
Plan Irregularities		Vertical Irregularities	
None		Steps in Elevation View: Single Change (Adjacent Building/Entity)	
None		None	
None		None	
Falling Hazards		Poor Conditions	
Other: General		None	
None		None	
None		None	
			
E Primary Structural Type falling hazard?		W Vertical Irregularity Primary	



Black Butte RFPD

Desc_fir01B

Black Butte RFPD

Building Type Fire - RFPD	County Deschutes	
Street 13511 Hawks Beard		
City Sisters	State OR	Zip 97759
Latitude 44.37939	Longitude 121.66295	
Tracking Code RVS in 2006	Inspection Date 6/27/2006	



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	RM1	3.6	-2	-0.5	0	0	-0.8	0	0	0.3
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Black Butte RFPD

Final RVS Score

Final Type	Final Score
RM1	0.3

FEMA-154 Collapse Potential

High (>10%)



OregonGeology

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
		1980	1980
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
	2	No	No
Plan Irregularities		Vertical Irregularities	
Reentrant Corners: L Shaped		Steps in Elevation View: Single Change (Adjacent Building/Entity)	
None		Steps in Elevation View: Single Change	
None		Vertical Lateral-Force-Resistance Element Displacement In Plane	
Falling Hazards		Poor Conditions	
None		None	
None		None	
None		None	
			
W Plan Irregularity Primary			

