

## La Pine RFPD

Building Type Fire - RFPD	County Deschutes	
Street 15990 Burges Rd		
City La Pine	State OR	Zip 97739
Latitude 43.70362	Longitude 121.52667	
Tracking Code RVS in 2006	Inspection Date 7/3/2006	



Seismicity Zone: Moderate										
FEMA 154 Rapid Visual Screening Score Card										
	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W1	5.2	-3.5	-0.5	0	0	0	-0.6	0	0.6
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

La Pine RFPD

Final RVS Score

Final Type W1	Final Score 0.6
------------------	--------------------

FEMA-154 Collapse Potential

High (>10%)
-------------

No  
Planview  
Available



Oregon Geology

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
		1992	1970
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
	1	No	No
Plan Irregularities		Vertical Irregularities	
Reentrant Corners: L Shaped		Steps in Elevation View: Single Change	
Torsion: Eccentric Stiffness		None	
None		None	
Falling Hazards		Poor Conditions	
None		None	
None		None	
None		None	
			
NE Plan Irregularity Primary			

