

Mountain View Senior High School

Bend-LaPine SD 1

Desc_sch05A

Building Type	County
School	Deschutes
Street	
2755 NE 27th St	
City	State Zip
Bend	OR 97701
Latitude	Longitude
44.07732	121.26564
Tracking Code	Inspection Date
RVS in 2006	6/30/2006



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	C3	3.2	-2	0	0	0	0	0	0	1.2
Secondary	RM1	3.6	-2	0	0	0	0	0	0	1.6
Tertiary		0	0	0	0	0	0	0	0	0

Mountain View Senior High School

Final RVS Score

Final Type	Final Score
C3	1.2

FEMA-154 Collapse Potential

Moderate (>1%)



OregonGeology

Mountain View Senior High School

Desc_sch05A

Enrollment 1570	Year Built (Field Verified) 1978	Year Built (Alt. Source) 1978	Est. Decade Built 1970
Total Area (square ft) 199440	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities None None None		Vertical Irregularities Steps in Elevation View: Single Change Steps in Elevation View: 2 to 3 Changes (Adjacent Building/Entity) None	
Falling Hazards None None None		Poor Conditions None None None	
 <p>NW General Site</p>			



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Mountain View Senior High School

Bend-LaPine SD 1

Desc_sch05B

Building Type	County	
School	Deschutes	
Street		
2755 NE 27th St		
City	State	Zip
Bend	OR	97701
Latitude	Longitude	
44.07754	121.26624	
Tracking Code	Inspection Date	
RVS in 2006	6/30/2006	



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	RM1	3.6	-2	-0.5	0	0	0	0	0	1.1
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Mountain View Senior High School

Final RVS Score

Final Type	Final Score
RM1	1.1

FEMA-154 Collapse Potential

Moderate (>1%)



OregonGeology

Mountain View Senior High School

Desc_sch05B

Enrollment 1570	Year Built (Field Verified) 1978	Year Built (Alt. Source) 1978	Est. Decade Built 1980
Total Area (square ft) 199440	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities Reentrant Corners:Other (Adjacent Build/Entity) None None		Vertical Irregularities Steps in Elevation View: Single Change (Adjacent Building/Entity) None None	
Falling Hazards None None None		Poor Conditions None None None	
 NE Vertical Irregularity Primary			

Mountain View Senior High School

Bend-LaPine SD 1

Desc_sch05C

Building Type School	County Deschutes	
Street 2755 NE 27th St		
City Bend	State OR	Zip 97701
Latitude 44.07798	Longitude 121.26545	
Tracking Code RVS in 2006	Inspection Date 6/30/2006	



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	RM1	3.6	0	0	0	0	0	0	0	3.6
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Mountain View Senior High School

Final RVS Score

Final Type RM1	Final Score 3.6
-------------------	--------------------

FEMA-154 Collapse Potential

Low (<1%)



Mountain View Senior High School

Desc_sch05C

Enrollment 1570	Year Built (Field Verified) 1978	Year Built (Alt. Source) 1978	Est. Decade Built 1980
Total Area (square ft) 199440	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities None None None		Vertical Irregularities None None None	
Falling Hazards None None None		Poor Conditions None None None	

Mountain View Senior High School

Bend-LaPine SD 1

Desc_sch05D

Building Type	County	
School	Deschutes	
Street		
2755 NE 27th St		
City	State	Zip
Bend	OR	97701
Latitude	Longitude	
44.07771	121.26504	
Tracking Code	Inspection Date	
RVS in 2006	6/30/2006	



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	RM1	3.6	0	0	0	0	0	0	0	3.6
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0


Mountain View Senior High School

Final RVS Score

Final Type	Final Score
RM1	3.6

FEMA-154 Collapse Potential

Low (<1%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Mountain View Senior High School

Desc_sch05D

Enrollment 1570	Year Built (Field Verified) 1978	Year Built (Alt. Source) 1978	Est. Decade Built 1980
Total Area (square ft) 199440	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities None None None		Vertical Irregularities None None None	
Falling Hazards None None None		Poor Conditions None None None	

Mountain View Senior High School

Bend-LaPine SD 1

Desc_sch05E

Building Type	County	
School	Deschutes	
Street		
2755 NE 27th St		
City	State	Zip
Bend	OR	97701
Latitude	Longitude	
44.07767	121.26695	
Tracking Code	Inspection Date	
RVS in 2006	6/30/2006	



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	RM1	3.6	-2	-0.5	0	0	0	0	0	1.1
Secondary	S2	3.6	-2	-0.5	0	0	0	0	0	1.1
Tertiary		0	0	0	0	0	0	0	0	0

Mountain View Senior High School

Final RVS Score

Final Type	Final Score
RM1	1.1

FEMA-154 Collapse Potential

Moderate (>1%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Mountain View Senior High School

Desc_sch05E

Enrollment 1570	Year Built (Field Verified) 1978	Year Built (Alt. Source) 1978	Est. Decade Built 1990
Total Area (square ft) 199440	Number of Stories 2	Basement	Pounding Potential No
Plan Irregularities		Vertical Irregularities	
Reentrant Corners: Other		Steps in Elevation View: Very Irregular Changes	
Large Diaphragm or Central Opening		Building On Hill or Sloped Site	
None		None	
Falling Hazards		Poor Conditions	
None		None	
None		None	
None		None	
			
NW Plan Irregularity Primary structural type; vert irregular; general site		N General Site	



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Mountain View Senior High School

Bend-LaPine SD 1

Desc_sch05F

Building Type	County
School	Deschutes
Street	
2755 NE 27th St	
City	State Zip
Bend	OR 97701
Latitude	Longitude
44.07706	121.26513
Tracking Code	Inspection Date
RVS in 2006	6/30/2006



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	RM1	3.6	-2	-0.5	0	0	0	0	0	1.1
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Mountain View Senior High School

Final RVS Score

Final Type	Final Score
RM1	1.1

FEMA-154 Collapse Potential

Moderate (>1%)



OregonGeology

Mountain View Senior High School

Desc_sch05F

Enrollment 1570	Year Built (Field Verified) 1978	Year Built (Alt. Source) 1978	Est. Decade Built 1980
Total Area (square ft) 199440	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities Reentrant Corners:Other (Adjacent Build/Entity) None None		Vertical Irregularities Steps in Elevation View: Single Change (Adjacent Building/Entity) None None	
Falling Hazards None None None		Poor Conditions None None None	

Mountain View Senior High School

Desc_sch05G

Bend-LaPine SD 1

Building Type School	County Deschutes	
Street 2755 NE 27th St		
City Bend	State OR	Zip 97701
Latitude 44.07728	Longitude 121.26495	
Tracking Code RVS in 2006	Inspection Date 6/30/2006	



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	RM1	3.6	-2	-0.5	0	0	0	0	0	1.1
Secondary	C3	3.2	-2	-0.5	0	0	0	0	0	0.7
Tertiary		0	0	0	0	0	0	0	0	0

Mountain View Senior High School

Final RVS Score

Final Type	Final Score
C3	0.7

FEMA-154 Collapse Potential

High (>10%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Mountain View Senior High School

Desc_sch05G

Enrollment 1570	Year Built (Field Verified) 1978	Year Built (Alt. Source) 1978	Est. Decade Built 1990
Total Area (square ft) 199440	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities Reentrant Corners:Other (Adjacent Build/Entity) None None		Vertical Irregularities Steps in Elevation View: Single Change (Adjacent Building/Entity) None None	
Falling Hazards None None None		Poor Conditions None None None	
			
S Secondary Structural Type possible c3			