

# John Tuck Elementary School

Redmond SD 2J

Desc\_sch08A

Building Type School	County Deschutes	
Street 209 NW 10th St		
City Redmond	State OR	Zip 97756
Latitude 44.27768	Longitude 121.17963	
Tracking Code RVS in 2006	Inspection Date 6/29/2006	



Seismicity Zone: Moderate

## FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	C2	3.6	-2	-0.5	0	0	0	0	0	1.1
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

John Tuck Elementary School

### Final RVS Score

Final Type	Final Score
C2	1.1

### FEMA-154 Collapse Potential

Moderate (>1%)



OregonGeology

# John Tuck Elementary School

Desc\_sch08A

Enrollment 502	Year Built (Field Verified) 1947	Year Built (Alt. Source) 1940	Est. Decade Built 1940
Total Area (square ft) 50425	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities Reentrant Corners:L shaped (Adjacent Build/Entity) None None		Vertical Irregularities Steps in Elevation View: 2 to 3 Changes (Adjacent Building/Entity) None None	
Falling Hazards Unreinforced Chimneys None None		Poor Conditions None None None	
 N Falling Hazard			



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment  
Oregon Department of Geology and Mineral Industries

# John Tuck Elementary School

Redmond SD 2J

Desc\_sch08B

Building Type School	County Deschutes	
Street 209 NW 10th St		
City Redmond	State OR	Zip 97756
Latitude 44.27788	Longitude 121.17909	
Tracking Code RVS in 2006	Inspection Date 6/29/2006	



Seismicity Zone: Moderate

## FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	C2	3.6	-2	0	0	0	0	0	0	1.6
Secondary	RM1	3.6	-2	0	0	0	0	0	0	1.6
Tertiary		0	0	0	0	0	0	0	0	0

John Tuck Elementary School

## Final RVS Score

Final Type	Final Score
C2	1.6

## FEMA-154 Collapse Potential

Moderate (>1%)



OregonGeology

# John Tuck Elementary School

Desc\_sch08B

Enrollment 502	Year Built (Field Verified) 1947	Year Built (Alt. Source) 1947	Est. Decade Built 1950
Total Area (square ft) 50425	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities None None None		Vertical Irregularities Steps in Elevation View: Single Change (Adjacent Building/Entity) None None	
Falling Hazards None None None		Poor Conditions None None None	

# John Tuck Elementary School

Redmond SD 2J

Desc\_sch08C

Building Type School	County Deschutes	
Street 209 NW 10th St		
City Redmond	State OR	Zip 97756
Latitude 44.27792	Longitude 121.18021	
Tracking Code RVS in 2006	Inspection Date 6/29/2006	



Seismicity Zone: Moderate

## FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	C2	3.6	-2	-0.5	0	0	0	0	0	1.1
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

John Tuck Elementary School

## Final RVS Score

Final Type	Final Score
C2	1.1

## FEMA-154 Collapse Potential

Moderate (>1%)



OregonGeology

# John Tuck Elementary School

Desc\_sch08C

Enrollment 502	Year Built (Field Verified) 1947	Year Built (Alt. Source) 1947	Est. Decade Built 1950
Total Area (square ft) 50425	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities Reentrant Corners:L shaped (Adjacent Build/Entity) None None		Vertical Irregularities Steps in Elevation View: Single Change (Adjacent Building/Entity) None None	
Falling Hazards None None None		Poor Conditions None None None	

# John Tuck Elementary School

Redmond SD 2J

Desc\_sch08D

Building Type School	County Deschutes	
Street 209 NW 10th St		
City Redmond	State OR	Zip 97756
Latitude 44.27812	Longitude 121.17908	
Tracking Code RVS in 2006	Inspection Date 6/29/2006	



Seismicity Zone: Moderate

## FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	RM1	3.6	0	0	0	0	0	0	0	3.6
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

John Tuck Elementary School

## Final RVS Score

Final Type	Final Score
RM1	3.6

## FEMA-154 Collapse Potential

Low (<1%)



OregonGeology

# John Tuck Elementary School

Desc\_sch08D

Enrollment 502	Year Built (Field Verified) 1947	Year Built (Alt. Source) 1947	Est. Decade Built 1980
Total Area (square ft) 50425	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities None None None		Vertical Irregularities None None None	
Falling Hazards None None None		Poor Conditions None None None	

# John Tuck Elementary School

Redmond SD 2J

Desc\_sch08E

Building Type School	County Deschutes	
Street 209 NW 10th St		
City Redmond	State OR	Zip 97756
Latitude 44.27767	Longitude 121.18029	
Tracking Code RVS in 2006	Inspection Date 6/29/2006	



Seismicity Zone: Moderate

## FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	4.8	-3	-0.5	0	1.6	0	0	0	2.9
Secondary	RM1	3.6	-2	-0.5	0	0	0	0	0	1.1
Tertiary		0	0	0	0	0	0	0	0	0

John Tuck Elementary School

### Final RVS Score

Final Type	Final Score
RM1	1.1

### FEMA-154 Collapse Potential

Moderate (>1%)



OregonGeology

# John Tuck Elementary School

Desc\_sch08E

Enrollment 502	Year Built (Field Verified) 1947	Year Built (Alt. Source) 1947	Est. Decade Built 1990
Total Area (square ft) 50425	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities Reentrant Corners:L shaped (Adjacent Build/Entity) None None		Vertical Irregularities Steps in Elevation View: 2 to 3 Changes None None	
Falling Hazards None None None		Poor Conditions None None None	
 <p>SW Vertical Irregularity Primary IRREGULARITIES AND REASON FOR POSSIBLE DIFFERENT STRUCTURAL TYPE.</p>			



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment  
Oregon Department of Geology and Mineral Industries