

# Terrebonne Community School

Redmond SD 2J

Desc\_sch10A

Building Type	County	
School	Deschutes	
Street		
1199 B Ave		
City	State	Zip
Terrebonne	OR	97760
Latitude	Longitude	
44.35179	121.1807	
Tracking Code	Inspection Date	
RVS in 2006	6/29/2006	



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	RM1	3.6	-2	-0.5	0	0	-0.8	0	0	0.3
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Terrebonne Community School

Final RVS Score

Final Type

Final Score

RM1

0.3

FEMA-154 Collapse Potential

High (>10%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment  
Oregon Department of Geology and Mineral Industries

# Terrebonne Community School

Desc\_sch10A

Enrollment 517	Year Built (Field Verified) 1940	Year Built (Alt. Source) 1940	Est. Decade Built 1970
Total Area (square ft) 34880	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities Reentrant Corners: L Shaped None None		Vertical Irregularities Steps in Elevation View: 2 to 3 Changes None None	
Falling Hazards None None None		Poor Conditions None None None	
 N Vertical Irregularity Primary			

# Terrebonne Community School

Redmond SD 2J

Desc\_sch10B

Building Type	County	
School	Deschutes	
Street		
1199 B Ave		
City	State	Zip
Terrebonne	OR	97760
Latitude	Longitude	
44.35155	121.18139	
Tracking Code	Inspection Date	
RVS in 2006	6/29/2006	



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	4.8	-3	-0.5	0	1.6	-0.8	0	0	2.1
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Terrebonne Community School

**Final RVS Score**

Final Type	Final Score
W2	2.1

**FEMA-154 Collapse Potential**

Low (<1%)
-----------



OregonGeology

# Terrebonne Community School

Desc\_sch10B

Enrollment 517	Year Built (Field Verified) 1940	Year Built (Alt. Source) 1940	Est. Decade Built 1980
Total Area (square ft) 34880	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities Reentrant Corners:L shaped (Adjacent Build/Entity) None None		Vertical Irregularities Steps in Elevation View: Single Change (Adjacent Building/Entity) None None	
Falling Hazards None None None		Poor Conditions None None None	
 S General Site			