

# Redmond High School

Redmond SD 2J

Desc\_sch13A

Building Type School	County Deschutes	
Street 675 SW Rimrock Dr		
City Redmond	State OR	Zip 97756
Latitude 44.27093	Longitude 121.19203	
Tracking Code RVS in 2006	Inspection Date 6/28/2006	



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	C2	3.6	-2	-0.5	0	0	0	0	0	1.1
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Redmond High School

Final RVS Score

Final Type	Final Score
C2	1.1

FEMA-154 Collapse Potential

Moderate (>1%)



OregonGeology

# Redmond High School

Desc\_sch13A

Enrollment 1802	Year Built (Field Verified) 1992	Year Built (Alt. Source) 1992	Est. Decade Built 1970
Total Area (square ft) 207480	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities Reentrant Corners: T shaped None None		Vertical Irregularities Steps in Elevation View: 2 to 3 Changes None None	
Falling Hazards None None None		Poor Conditions None None None	
 W Primary Structural Type		 E Elevation View .plan vert irregular	



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment  
Oregon Department of Geology and Mineral Industries

# Redmond High School

Redmond SD 2J

Desc\_sch13B

Building Type School	County Deschutes	
Street 675 SW Rimrock Dr		
City Redmond	State OR	Zip 97756
Latitude 44.2717	Longitude 121.19079	
Tracking Code RVS in 2006	Inspection Date 6/28/2006	



Seismicity Zone: Moderate

## FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	RM1	3.6	0	-0.5	0	0	0	0	0	3.1
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Redmond High School

### Final RVS Score

Final Type	Final Score
RM1	3.1

### FEMA-154 Collapse Potential

Low (<1%)



OregonGeology

# Redmond High School

Desc\_sch13B

Enrollment 1802	Year Built (Field Verified) 1992	Year Built (Alt. Source) 1992	Est. Decade Built 1970
Total Area (square ft) 207480	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities Reentrant Corners:T shaped (Adjacent Build/Entity) None None		Vertical Irregularities None None None	
Falling Hazards None None None		Poor Conditions None None None	

# Redmond High School

Redmond SD 2J

Desc\_sch13C

Building Type School	County Deschutes	
Street 675 SW Rimrock Dr		
City Redmond	State OR	Zip 97756
Latitude 44.27035	Longitude 121.19264	
Tracking Code RVS in 2006	Inspection Date 6/28/2006	



Seismicity Zone: Moderate

## FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	RM1	3.6	-2	0	0	0	0	0	0	1.6
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Redmond High School

## Final RVS Score

Final Type	Final Score
RM1	1.6

## FEMA-154 Collapse Potential

Moderate (>1%)



OregonGeology

# Redmond High School

Desc\_sch13C

Enrollment 1802	Year Built (Field Verified) 1992	Year Built (Alt. Source) 1992	Est. Decade Built 1980
Total Area (square ft) 207480	Number of Stories 1	Basement No	Pounding Potential No
Plan Irregularities		Vertical Irregularities	
Reentrant Corners: Other None None		Steps in Elevation View: 2 to 3 Changes None None	
Falling Hazards None None None		Poor Conditions None None None	



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment  
Oregon Department of Geology and Mineral Industries

# Redmond High School

Desc\_sch13D

Redmond SD 2J

Building Type School	County Deschutes	
Street 675 SW Rimrock Dr		
City Redmond	State OR	Zip 97756
Latitude 44.27176	Longitude 121.1923	
Tracking Code RVS in 2006	Inspection Date 6/28/2006	



Seismicity Zone: Moderate

## FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	RM1	3.6	-2	0	0	0	0	0	0	1.6
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Redmond High School

## Final RVS Score

Final Type	Final Score
RM1	1.6

## FEMA-154 Collapse Potential

Moderate (>1%)



OregonGeology

Enrollment 1802	Year Built (Field Verified) 1992	Year Built (Alt. Source) 1992	Est. Decade Built 1990
Total Area (square ft) 207480	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities		Vertical Irregularities	
Reentrant Corners:L shaped (Adjacent Build/Entity)		Steps in Elevation View: Single Change (Adjacent Building/Entity)	
None		None	
None		None	
Falling Hazards		Poor Conditions	
None		None	
None		None	
None		None	

