

Three Rivers Elementary School

Desc_sch15A

Bend-LaPine SD 1

Building Type		County	
School		Deschutes	
Street			
56900 Enterprise Dr.			
City	State	Zip	
Sunriver	OR	97707	
Latitude	Longitude		
43.8679	121.43367		
Tracking Code	Inspection Date		
RVS in 2006	7/3/2006		



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	4.8	0	0	0	1.6	0	0	0	6.4
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Three Rivers Elementary School

Final RVS Score

Final Type

Final Score

W2

6.4

FEMA-154 Collapse Potential

Low (<1%)

**No
Planview
Available**



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
437		1989	1980
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
34210	1	No	No

Plan Irregularities	Vertical Irregularities
None	None
None	None
None	None

Falling Hazards	Poor Conditions
None	None
None	None
None	None

