

LaPine Middle School

Bend-LaPine SD 1

Desc_sch20A

Building Type		County	
School		Deschutes	
Street			
16360 First St			
City	State	Zip	
La Pine	OR	97739	
Latitude		Longitude	
43.67631		121.50837	
Tracking Code		Inspection Date	
RVS in 2006		6/30/2006	



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	RM1	3.6	-2	-0.5	0	0	0	-1.2	0	-0.1
Secondary	S3	3.8	0	-0.5	0	0	0	-1	0	2.3
Tertiary	S2	3.6	-2	-0.5	0	0	0	-1.2	0	-0.1

LaPine Middle School

Final RVS Score

Final Type

Final Score

RM1

-0.1

FEMA-154 Collapse Potential

Very High (100%)




OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
518	1980	1980	1980
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
72517	1	No	No

Plan Irregularities	Vertical Irregularities
Reentrant Corners: H Shaped	Steps in Elevation View: 2 to 3 Changes
None	None
None	None

Falling Hazards	Poor Conditions
None	None
None	None
None	None




E Primary Structural Type



N Field Verified Year Built



W Secondary Structural Type



N General Site

LaPine Middle School

Desc_sch20B

Bend-LaPine SD 1

Building Type		County	
School		Deschutes	
Street			
16360 First St			
City	State	Zip	
La Pine	OR	97739	
Latitude		Longitude	
43.6759		121.50913	
Tracking Code		Inspection Date	
RVS in 2006		6/30/2006	



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	S3	3.8	0	0	0	0	0	-1	0	2.8
Secondary	S2	3.6	0	0	0	0	0	-1.2	0	2.4
Tertiary		0	0	0	0	0	0	0	0	0

LaPine Middle School

Final RVS Score

Final Type

Final Score

S2

2.4

FEMA-154 Collapse Potential

Low (<1%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
518		1980	1970
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
72517	1	No	No

Plan Irregularities	Vertical Irregularities
None	None
None	None
None	None

Falling Hazards	Poor Conditions
None	None
None	None
None	None