


Juniper Elementary School

Bend-LaPine SD 1

Desc_sch33A

Building Type School	County Deschutes	
Street 1300 Ne Norton St		
City Bend	State OR	Zip 97701
Latitude 44.06388	Longitude 121.28822	
Tracking Code RVS in 2006	Inspection Date 7/5/2006	



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	C2	3.6	-2	-0.5	0	0	0	-1.2	0	-0.1
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Juniper Elementary School

Final RVS Score

Final Type	Final Score
C2	-0.1

FEMA-154 Collapse Potential

Very High (100%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Juniper Elementary School

Desc_sch33A

Enrollment 408	Year Built (Field Verified) 1965	Year Built (Alt. Source) 1965	Est. Decade Built 1960
Total Area (square ft) 52134	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities Reentrant Corners: L Shaped None None		Vertical Irregularities Steps in Elevation View: Single Change Building On Hill or Sloped Site None	
Falling Hazards None None None		Poor Conditions None None None	
			
SW Vertical Irregularity Primary		NW General Site	NE General Site

Juniper Elementary School

Bend-LaPine SD 1

Desc_sch33B

Building Type School	County Deschutes	
Street 1300 Ne Norton St		
City Bend	State OR	Zip 97701
Latitude 44.06461	Longitude 121.28825	
Tracking Code RVS in 2006	Inspection Date 7/5/2006	



Seismicity Zone: Moderate										
FEMA 154 Rapid Visual Screening Score Card										
	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	4.8	0	-0.5	0	0	0	-1.2	0	3.1
Secondary	RM1	3.6	0	-0.5	0	0	0	-1.2	0	1.9
Tertiary		0	0	0	0	0	0	0	0	0

Juniper Elementary School

Final RVS Score

Final Type RM1	Final Score 1.9
-------------------	--------------------

FEMA-154 Collapse Potential

Moderate (>1%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Juniper Elementary School

Desc_sch33B

Enrollment 408	Year Built (Field Verified) 1965	Year Built (Alt. Source) 1965	Est. Decade Built 1970
Total Area (square ft) 52134	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities Reentrant Corners: T shaped None None		Vertical Irregularities None None None	
Falling Hazards None None None		Poor Conditions None None None	
 SE Plan Irregularity Primary		 NE General Site	



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Juniper Elementary School

Bend-LaPine SD 1

Desc_sch33C

Building Type School	County Deschutes	
Street 1300 Ne Norton St		
City Bend	State OR	Zip 97701
Latitude 44.06437	Longitude 121.28762	
Tracking Code RVS in 2006	Inspection Date 7/5/2006	



Seismicity Zone: Moderate										
FEMA 154 Rapid Visual Screening Score Card										
	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	4.8	0	-0.5	0	0	0	-1.2	0	3.1
Secondary	RM1	3.6	0	-0.5	0	0	0	-1.2	0	1.9
Tertiary		0	0	0	0	0	0	0	0	0

Juniper Elementary School

Final RVS Score

Final Type	Final Score
RM1	1.9

FEMA-154 Collapse Potential

Moderate (>1%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Juniper Elementary School

Desc_sch33C

Enrollment 408	Year Built (Field Verified) 1965	Year Built (Alt. Source) 1965	Est. Decade Built 1970
Total Area (square ft) 52134	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities Reentrant Corners: T shaped None None		Vertical Irregularities None None None	
Falling Hazards None None None		Poor Conditions None None None	
			
SE Plan Irregularity Primary		SE General Site	



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Juniper Elementary School

Bend-LaPine SD 1

Desc_sch33D

Building Type School	County Deschutes	
Street 1300 Ne Norton St		
City Bend	State OR	Zip 97701
Latitude 44.064	Longitude 121.28746	
Tracking Code RVS in 2006	Inspection Date 7/5/2006	



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	4.8	0	-0.5	0	0	0	-1.2	0	3.1
Secondary	RM1	3.6	0	-0.5	0	0	0	-1.2	0	1.9
Tertiary		0	0	0	0	0	0	0	0	0

Juniper Elementary School

Final RVS Score

Final Type	Final Score
RM1	1.9

FEMA-154 Collapse Potential

Moderate (>1%)



OregonGeology

Juniper Elementary School

Desc_sch33D

Enrollment 408	Year Built (Field Verified) 1965	Year Built (Alt. Source) 1965	Est. Decade Built 1970
Total Area (square ft) 52134	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities Reentrant Corners: Other None None		Vertical Irregularities None None None	
Falling Hazards None None None		Poor Conditions None None None	
 N Plan Irregularity Primary		 S Plan Irregularity Primary	



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Juniper Elementary School

Bend-LaPine SD 1

Desc_sch33E

Building Type School	County Deschutes	
Street 1300 Ne Norton St		
City Bend	State OR	Zip 97701
Latitude 44.06358	Longitude 121.28774	
Tracking Code RVS in 2006	Inspection Date 7/5/2006	



Seismicity Zone: Moderate										
FEMA 154 Rapid Visual Screening Score Card										
	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	4.8	0	-0.5	0	0	0	-1.2	0	3.1
Secondary	RM1	3.6	0	-0.5	0	0	0	-1.2	0	1.9
Tertiary		0	0	0	0	0	0	0	0	0

Juniper Elementary School

Final RVS Score

Final Type	Final Score
RM1	1.9

FEMA-154 Collapse Potential

Moderate (>1%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Juniper Elementary School

Desc_sch33E

Enrollment 408	Year Built (Field Verified) 1965	Year Built (Alt. Source) 1965	Est. Decade Built 1970
Total Area (square ft) 52134	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities Reentrant Corners: L Shaped None None		Vertical Irregularities None Building On Hill or Sloped Site None	
Falling Hazards None None None		Poor Conditions None None None	
 NW Plan Irregularity Primary			

Juniper Elementary School

Bend-LaPine SD 1

Desc_sch33F

Building Type School	County Deschutes	
Street 1300 Ne Norton St		
City Bend	State OR	Zip 97701
Latitude 44.06375	Longitude 121.28789	
Tracking Code RVS in 2006	Inspection Date 7/5/2006	



Seismicity Zone: Moderate										
FEMA 154 Rapid Visual Screening Score Card										
	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	4.8	-3	0	0	1.6	0	-1.2	0	2.2
Secondary	RM1	3.6	-2	0	0	0	0	-1.2	0	0.4
Tertiary		0	0	0	0	0	0	0	0	0

Juniper Elementary School

Final RVS Score

Final Type	Final Score
RM1	0.4

FEMA-154 Collapse Potential

High (>10%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Juniper Elementary School

Desc_sch33F

Enrollment 408	Year Built (Field Verified) 1965	Year Built (Alt. Source) 1965	Est. Decade Built 1990
Total Area (square ft) 52134	Number of Stories 1	Basement	Pounding Potential Yes
Plan Irregularities None None None		Vertical Irregularities Building On Hill or Sloped Site None None	
Falling Hazards None None None		Poor Conditions None None None	
 W Other			