


# Amity Creek Elementary School

Bend-LaPine SD 1

Desc\_sch36A

Building Type School	County Deschutes	
Street 437 NW Wall St		
City Bend	State OR	Zip 97701
Latitude 44.05512	Longitude 121.31791	
Tracking Code RVS in 2006	Inspection Date 7/5/2006	



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	URM	3.4	-1.5	-0.5	-0.4	0	0	0	0	1
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Amity Creek Elementary School

Final RVS Score

Final Type URM	Final Score 1
-------------------	------------------

FEMA-154 Collapse Potential

High (>10%)
-------------



OregonGeology

# Amity Creek Elementary School

Desc\_sch36A

Enrollment 157	Year Built (Field Verified) 1925	Year Built (Alt. Source) 1920	Est. Decade Built 1920
Total Area (square ft) 62592	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities Reentrant Corners: T shaped None None		Vertical Irregularities Steps in Elevation View: Single Change (Adjacent Building/Entity) None None	
Falling Hazards Parapets: Unreinforced Around Entire Building Other: Ornamental Hazard Over Exit None		Poor Conditions Cracks None None	
			
S Plan Irregularity Primary		S Poor Condition	
		NW General Site	
		SE General Site	
		W Falling Hazard	
		NW Vertical Irregularity Primary	



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment  
Oregon Department of Geology and Mineral Industries

# Amity Creek Elementary School

Bend-LaPine SD 1

Desc\_sch36B

Building Type School	County Deschutes	
Street 437 NW Wall St		
City Bend	State OR	Zip 97701
Latitude 44.05542	Longitude 121.31793	
Tracking Code RVS in 2006	Inspection Date 7/5/2006	



Seismicity Zone: Moderate

## FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	C2	3.6	-2	-0.5	-0.4	0	0	0	0	0.7
Secondary	RM1	3.6	-2	-0.5	-0.4	0	0	0	0	0.7
Tertiary		0	0	0	0	0	0	0	0	0

Amity Creek Elementary School

## Final RVS Score

Final Type	Final Score
C2	0.7

## FEMA-154 Collapse Potential

High (>10%)



OregonGeology

# Amity Creek Elementary School

Desc\_sch36B

Enrollment 157	Year Built (Field Verified) 1925	Year Built (Alt. Source) 1925	Est. Decade Built 1940
Total Area (square ft) 62592	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities Reentrant Corners: T shaped None None		Vertical Irregularities Steps in Elevation View: Single Change (Adjacent Building/Entity) None None	
Falling Hazards None None None		Poor Conditions Cracks None None	