

# North Douglas County Fire & EMS

North Douglas County Fire & EMS

Doug\_fir04A

Building Type	County	
Fire - RFPD	Douglas	
Street		
222 Alder St		
City	State	Zip
Yoncalla	OR	97499
Latitude	Longitude	
43.59958	123.28309	
Tracking Code	Inspection Date	
RVS in 2006	8/9/2006	



Seismicity Zone: High

## FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	S3	3.2	0	-0.5	0	0	-0.4	0	0	2.3
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

North Douglas County Fire & EMS

## Final RVS Score

Final Type	Final Score
S3	2.3

## FEMA-154 Collapse Potential

Low (<1%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment  
Oregon Department of Geology and Mineral Industries

# North Douglas County Fire & EMS

Doug\_fir04A

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
			1990
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
	1	No	No
Plan Irregularities		Vertical Irregularities	
Torsion: Eccentric Stiffness		None	
None		None	
None		None	
Falling Hazards		Poor Conditions	
None		None	
None		None	
None		None	
			
N Elevation View			