

Douglas County Fire District 2 - Fire Station #4 - Winc

Doug_fir05A

Douglas Co Fire Dist #2

Building Type	County	
Fire - RFPD	Douglas	
Street		
6576 Old Hwy 99 N		
City	State	Zip
Winchester	OR	97470
Latitude	Longitude	
43.29151	123.35235	
Tracking Code	Inspection Date	
RVS in 2006	8/28/2006	



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	3.8	0	0	0	0	0	0	0	3.8
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Douglas County Fire District 2 - Fire Station #4 - Winchester

Final RVS Score

Final Type	Final Score
W2	3.8

FEMA-154 Collapse Potential

Low (<1%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Douglas County Fire District 2 - Fire Station #4 - Winche

Doug_fir05A

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
			1970
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
	1	Yes	No
Plan Irregularities		Vertical Irregularities	
None		None	
None		None	
None		None	
Falling Hazards		Poor Conditions	
None		None	
None		None	
None		None	
			
SW Elevation View Basement		N Elevation View	
			
		E Elevation View	



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries