

Douglas County Fire District 2

Douglas Co Fire Dist #2

Doug_fir08A

Building Type Fire - RFPD	County Douglas	
Street 6000 Garden Valley Rd		
City Roseburg	State OR	Zip 97470
Latitude 43.28324	Longitude 123.41146	
Tracking Code RVS in 2006	Inspection Date 8/10/2006	



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W1	4.4	-2.5	-0.5	0	2.4	0	0	0	3.8
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Douglas County Fire District 2

Final RVS Score

Final Type	Final Score
W1	3.8

FEMA-154 Collapse Potential

Low (<1%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Douglas County Fire District 2

Doug_fir08A

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
			1990
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
	2	No	No
Plan Irregularities		Vertical Irregularities	
Reentrant Corners: Other		Steps in Elevation View: 2 to 3 Changes	
Torsion: Eccentric Stiffness		None	
None		None	
Falling Hazards		Poor Conditions	
None		None	
None		None	
None		None	
			
S Vertical Irregularity Primary reentrant corner also		E Primary Structural Type	



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries