

# Roseburg FD

City of Roseburg

Doug\_fir12A

Building Type Fire - City	County Douglas	
Street 2177 W Harvard Ave		
City Roseburg	State OR	Zip 97470
Latitude 43.21421	Longitude 123.37752	
Tracking Code RVS in 2006	Inspection Date 8/18/2006	



Seismicity Zone: High

## FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	C2	2.8	-1	-0.5	0	0	-0.4	0	0	0.9
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Roseburg FD

## Final RVS Score

Final Type	Final Score
C2	0.9

## FEMA-154 Collapse Potential

High (>10%)



OregonGeology

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
	1954	1954	1950
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
	1	No	No
Plan Irregularities		Vertical Irregularities	
Reentrant Corners: Other		Steps in Elevation View: Single Change	
None		None	
None		None	
Falling Hazards		Poor Conditions	
Other: Smokestack		None	
None		None	
None		None	
			
N Field Verified Year Built 1954 date		SW Falling Hazard also step in elevation and reentrant corner	
		W Elevation View	
			
W Primary Structural Type pour lines of cast in-place C2		W Primary Structural Type solid C2 wall	

